

Network Working Group
Internet-Draft
Intended status: Standards Track
Expires: May 16, 2015

C. Jennings
Cisco
Z. Shelby
ARM
J. Arkko
Ericsson
November 12, 2014

Media Types for Sensor Markup Language (SENML)
draft-jennings-core-senml-00

Abstract

This specification defines media types for representing simple sensor measurements and device parameters in the Sensor Markup Language (SenML). Representations are defined in JavaScript Object Notation (JSON), eXtensible Markup Language (XML) and Efficient XML Interchange (EXI), which share the common SenML data model. A simple sensor, such as a temperature sensor, could use this media type in protocols such as HTTP or CoAP to transport the measurements of the sensor or to be configured.

Status of this Memo

This Internet-Draft is submitted in full conformance with the provisions of [BCP 78](#) and [BCP 79](#).

Internet-Drafts are working documents of the Internet Engineering Task Force (IETF). Note that other groups may also distribute working documents as Internet-Drafts. The list of current Internet-Drafts is at <http://datatracker.ietf.org/drafts/current/>.

Internet-Drafts are draft documents valid for a maximum of six months and may be updated, replaced, or obsoleted by other documents at any time. It is inappropriate to use Internet-Drafts as reference material or to cite them other than as "work in progress."

This Internet-Draft will expire on May 16, 2015.

Copyright Notice

Copyright (c) 2014 IETF Trust and the persons identified as the document authors. All rights reserved.

This document is subject to [BCP 78](#) and the IETF Trust's Legal Provisions Relating to IETF Documents (<http://trustee.ietf.org/license-info>) in effect on the date of

publication of this document. Please review these documents carefully, as they describe your rights and restrictions with respect to this document. Code Components extracted from this document must include Simplified BSD License text as described in Section 4.e of the Trust Legal Provisions and are provided without warranty as described in the Simplified BSD License.

Table of Contents

1.	Overview	3
2.	Requirements and Design Goals	3
3.	Terminology	4
4.	Semantics	4
5.	Associating Meta-data	7
6.	JSON Representation (application/senml+json)	7
6.1.	Examples	9
6.1.1.	Single Datapoint	9
6.1.2.	Multiple Datapoints	9
6.1.3.	Multiple Measurements	10
6.1.4.	Collection of Resources	10
7.	XML Representation (application/senml+xml)	11
8.	EXI Representation (application/senml-exi)	12
9.	Usage Considerations	14
10.	IANA Considerations	15
10.1.	Units Registry	15
10.2.	Media Type Registration	18
10.2.1.	senml+json Media Type Registration	18
10.2.2.	senml+xml Media Type Registration	19
10.2.3.	senml-exi Media Type Registration	20
10.3.	XML Namespace Registration	21
11.	Security Considerations	21
12.	Privacy Considerations	21
13.	Acknowledgement	21
14.	References	22
14.1.	Normative References	22
14.2.	Informative References	22
	Authors' Addresses	23

1. Overview

Connecting sensors to the internet is not new, and there have been many protocols designed to facilitate it. This specification defines new media types for carrying simple sensor information in a protocol such as HTTP or CoAP[RFC7252] called the Sensor Markup Language (SenML). This format was designed so that processors with very limited capabilities could easily encode a sensor measurement into the media type, while at the same time a server parsing the data could relatively efficiently collect a large number of sensor measurements. There are many types of more complex measurements and measurements that this media type would not be suitable for. A decision was made not to carry most of the meta data about the sensor in this media type to help reduce the size of the data and improve efficiency in decoding. Instead meta-data about a sensor resource can be described out-of-band using the CoRE Link Format [RFC6690]. The markup language can be used for a variety of data flow models, most notably data feeds pushed from a sensor to a collector, and the web resource model where the sensor is requested as a resource representation (GET /sensor/temperature).

SenML is defined by a data model for measurements and simple meta-data about measurements and devices. The data is structured as a single object (with attributes) that contains an array of entries. Each entry is an object that has attributes such as a unique identifier for the sensor, the time the measurement was made, and the current value. Serializations for this data model are defined for JSON [RFC4627], XML and Efficient XML Interchange (EXI) [W3C.REC-exi-20110310].

For example, the following shows a measurement from a temperature gauge encoded in the JSON syntax.

```
{"e":[{"n": "urn:dev:ow:10e2073a01080063", "v":23.5, "u":"Cel" }]}
```

In the example above, the array in the object has a single measurement for a sensor named "urn:dev:ow:10e2073a01080063" with a temperature of 23.5 degrees Celsius.

2. Requirements and Design Goals

The design goal is to be able to send simple sensor measurements in small packets on mesh networks from large numbers of constrained devices. Keeping the total size under 80 bytes makes this easy to use on a wireless mesh network. It is always difficult to define what small code is, but there is a desire to be able to implement this in roughly 1 KB of flash on a 8 bit microprocessor. Experience with Google power meter and large scale deployments has indicated

that the solution needs to support allowing multiple measurements to be batched into a single HTTP or CoAP request. This "batch" upload capability allows the server side to efficiently support a large number of devices. It also conveniently supports batch transfers from proxies and storage devices, even in situations where the sensor itself sends just a single data item at a time. The multiple measurements could be from multiple related sensors or from the same sensor but at different times.

3. Terminology

The key words "MUST", "MUST NOT", "REQUIRED", "SHALL", "SHALL NOT", "SHOULD", "SHOULD NOT", "RECOMMENDED", "MAY", and "OPTIONAL" in this document are to be interpreted as described in [RFC 2119](#) [[RFC2119](#)].

4. Semantics

Each representation carries a single SenML object that represents a set of measurements and/or parameters. This object contains several optional attributes described below and a mandatory array of one or more entries.

Base Name

This is a string that is prepended to the names found in the entries. This attribute is optional.

Base Time

A base time that is added to the time found in an entry. This attribute is optional.

Base Units

A base unit that is assumed for all entries, unless otherwise indicated. This attribute is optional.

Version

Version number of media type format. This attribute is optional positive integer and defaults to 1 if not present.

Measurement or Parameter Entries

Array of values for sensor measurements or other generic parameters (such as configuration parameters). If present there must be at least one entry in the array.

Each array entry contains several attributes, some of which are optional and some of which are mandatory.

Name

Name of the sensor or parameter. When appended to the Base Name attribute, this must result in a globally unique identifier for the resource. The name is optional, if the Base Name is present. If the name is missing Base Name must uniquely identify the resource. This can be used to represent a large array of measurements from the same sensor without having to repeat its identifier on every measurement.

Units

Units for a measurement value.

Value

Value of the entry. Optional if a Sum value is present, otherwise required. Values are represented using three basic data types, Floating point numbers ("v" field for "Value"), Booleans ("bv" for "Boolean Value") and Strings ("sv" for "String Value"). Exactly one of these three fields MUST appear.

Sum

Integrated sum of the values over time. Optional. This attribute is in the units specified in the Unit value multiplied by seconds.

Time

Time when value was recorded. Optional.

Update Time

Update time. A time in seconds that represents the maximum time before this sensor will provide an updated reading for a measurement. This can be used to detect the failure of sensors or communications path from the sensor. Optional.

The SenML format can be extended with further custom attributes placed in the base object, or in an entry. Extensions in the base object pertain to all entries, whereas extensions in an entry object only pertain to that.

Systems reading one of the objects MUST check for the Version attribute. If this value is a version number larger than the version which the system understands, the system SHOULD NOT use this object. This allows the version number to indicate that the object contains mandatory to understand attributes. New version numbers can only be defined in RFC which updates this specification or its successors.

The Name value is concatenated to the Base Name value to get the name of the sensor. The resulting name needs to uniquely identify and differentiate the sensor from all others. If the object is a representation resulting from the request of a URI [[RFC3986](#)], then in the absence of the Base Name attribute, this URI is used as the default value of Base Name. Thus in this case the Name field needs to be unique for that URI, for example an index or subresource name of sensors handled by the URI.

Alternatively, for objects not related to a URI, a unique name is required. In any case, it is RECOMMENDED that the full names are represented as URIs or URNs [[RFC2141](#)]. One way to create a unique name is to include a EUI-48 or EUI-64 identifier (A MAC address) or some other bit string that is guaranteed uniqueness (such as a 1-wire address) that is assigned to the device. Some of the examples in this draft use the device URN type as specified in [[I-D.arkko-core-dev-urn](#)]. UUIDs [[RFC4122](#)] are another way to generate a unique name.

The resulting concatenated name MUST consist only of characters out of the set "A" to "Z", "a" to "z", "0" to "9", "-", ":", ".", or "_" and it MUST start with a character out of the set "A" to "Z", "a" to "z", or "0" to "9". This restricted character set was chosen so that these names can be directly used as in other types of URI including segments of an HTTP path with no special encoding. [[RFC5952](#)] contains advice on encoding an IPv6 address in a name.

If either the Base Time or Time value is missing, the missing attribute is considered to have a value of zero. The Base Time and Time values are added together to get the time of measurement. A time of zero indicates that the sensor does not know the absolute time and the measurement was made roughly "now". A negative value is used to indicate seconds in the past from roughly "now". A positive value is used to indicate the number of seconds, excluding leap seconds, since the start of the year 1970 in UTC .

Representing the statistical characteristics of measurements can be very complex. Future specification may add new attributes to provide better information about the statistical properties of the measurement.

5. Associating Meta-data

SenML is designed to carry the minimum dynamic information about measurements, and for efficiency reasons does not carry more static meta-data about the device, object or sensors. Instead, it is assumed that this meta-data is carried out of band. For web resources using SenML representations, this meta-data can be made available using the CoRE Link Format [[RFC6690](#)].

The CoRE Link Format provides a simple way to describe Web Links, and in particular allows a web server to describe resources it is hosting. The list of links that a web server has available, can be discovered by retrieving the /.well-known/core resource, which returns the list of links in the CoRE Link Format. Each link may contain attributes, for example title, resource type, interface description and content-type.

The most obvious use of this link format is to describe that a resource is available in a SenML format in the first place. The relevant media type indicator is included in the Content-Type (ct=) attribute.

Further semantics about a resource can be included in the Resource Type and Interface Description attributes. The Resource Type (rt=) attribute is meant to give a semantic meaning to that resource. For example rt="outdoor-temperature" would indicate static semantic meaning in addition to the unit information included in SenML. The Interface Description (if=) attribute is used to describe the REST interface of a resource, and may include e.g. a reference to a WADL description [[WADL](#)].

6. JSON Representation (application/senml+json)

Root variables:

SenML	JSON	Type
Base Name	bn	String
Base Time	bt	Number
Base Units	bu	Number
Version	ver	Number
Measurement or Parameters	e	Array

Measurement or Parameter Entries:

SenML	JSON	Notes
Name	n	String
Units	u	String
Value	v	Floating point
String Value	sv	String
Boolean Value	bv	Boolean
Value Sum	s	Floating point
Time	t	Number
Update Time	ut	Number

All of the data is UTF-8, but since this is for machine to machine communications on constrained systems, only characters with code points between U+0001 and U+007F are allowed which corresponds to the ASCII[RFC0020] subset of UTF-8.

The root contents MUST consist of exactly one JSON object as specified by [RFC4627]. This object MAY contain a "bn" attribute with a value of type string. This object MAY contain a "bt" attribute with a value of type number. The object MAY contain a "bu" attribute with a value of type string. The object MAY contain a "ver" attribute with a value of type number. The object MAY contain other attribute value pairs, and the object MUST contain exactly one "e" attribute with a value of type array. The array MUST have one or more measurement or parameter objects.

Inside each measurement or parameter object the "n", "u", and "sv" attributes are of type string, the "t" and "ut" attributes are of type number, the "bv" attribute is of type boolean, and the "v" and "s" attributes are of type floating point. All the attributes are optional, but as specified in [Section 4](#), one of the "v", "sv", or "bv" attributes MUST appear unless the "s" attribute is also present. The "v", and "sv", and "bv" attributes MUST NOT appear together.

Systems receiving measurements MUST be able to process the range of floating point numbers that are representable as an IEEE double-precision floating-point numbers [[IEEE.754.1985](#)]. The number of significant digits in any measurement is not relevant, so a reading of 1.1 has exactly the same semantic meaning as 1.10. If the value has an exponent, the "e" MUST be in lower case. The mantissa SHOULD be less than 19 characters long and the exponent SHOULD be less than 5 characters long. This allows time values to have better than micro second precision over the next 100 years.

[6.1.](#) Examples

[6.1.1.](#) Single Datapoint

The following shows a temperature reading taken approximately "now" by a 1-wire sensor device that was assigned the unique 1-wire address of 10e2073a01080063:

```
{"e":[{"n": "urn:dev:ow:10e2073a01080063", "v":23.5 }]}
```

[6.1.2.](#) Multiple Datapoints

The following example shows voltage and current now, i.e., at an unspecified time. The device has an EUI-64 MAC address of 0024beffffe804ff1.

```
{"e":[{"n": "voltage", "t": 0, "u": "V", "v": 120.1 },
{"n": "current", "t": 0, "u": "A", "v": 1.2 }],
"bn": "urn:dev:mac:0024beffffe804ff1/"
}
```

The next example is similar to the above one, but shows current at Tue Jun 8 18:01:16 UTC 2010 and at each second for the previous 5 seconds.

```
{"e":[{"n": "voltage", "u": "V", "v": 120.1 },
{"n": "current", "t": -5, "v": 1.2 },
{"n": "current", "t": -4, "v": 1.30 },
{"n": "current", "t": -3, "v": 0.14e1 },
{"n": "current", "t": -2, "v": 1.5 },
{"n": "current", "t": -1, "v": 1.6 },
{"n": "current", "t": 0, "v": 1.7 }],
"bn": "urn:dev:mac:0024beffffe804ff1/",
"bt": 1276020076,
"ver": 1,
"bu": "A"
}
```



```
}
```

6.1.3. Multiple Measurements

The following example shows humidity measurements from a mobile device with an IPv6 address 2001:db8::1, starting at Mon Oct 31 13:24:24 UTC 2011. The device also provide position data, which is provided in the same measurement or parameter array as separate entries. Note time is used to for correlating data that belongs together, e.g., a measurement and a parameter associated with it. Finally, the device also reports extra data about its battery status at a separate time.

```
{ "e": [
  { "v": 20.0, "t": 0 },
  { "sv": "E 24' 30.621", "u": "lon", "t": 0 },
  { "sv": "N 60' 7.965", "u": "lat", "t": 0 },
  { "v": 20.3, "t": 60 },
  { "sv": "E 24' 30.622", "u": "lon", "t": 60 },
  { "sv": "N 60' 7.965", "u": "lat", "t": 60 },
  { "v": 20.7, "t": 120 },
  { "sv": "E 24' 30.623", "u": "lon", "t": 120 },
  { "sv": "N 60' 7.966", "u": "lat", "t": 120 },
  { "v": 98.0, "u": "%EL", "t": 150 },
  { "v": 21.2, "t": 180 },
  { "sv": "E 24' 30.628", "u": "lon", "t": 180 },
  { "sv": "N 60' 7.967", "u": "lat", "t": 180 }],
  "bn": "http://[2001:db8::1]",
  "bt": 1320067464,
  "bu": "%RH"
}
```

6.1.4. Collection of Resources

The following example shows how to query one device that can provide multiple measurements. The example assumes that a client has fetched information from a device at 2001:db8::2 by performing a GET operation on http://[2001:db8::2] at Mon Oct 31 16:27:09 UTC 2011, and has gotten two separate values as a result, a temperature and humidity measurement.

```
{ "e": [
  { "n": "temperature", "v": 27.2, "u": "Cel" },
  { "n": "humidity", "v": 80, "u": "%RH" } ],
  "bn": "http://[2001:db8::2]/",
  "bt": 1320078429,
  "ver": 1
}
```


7. XML Representation (application/senml+xml)

A SenML object can also be represented in XML format as defined in this section. The following example shows an XML example for the same sensor measurement as in [Section 6.1.2](#).

```
<?xml version="1.0" encoding="UTF-8"?>
<senml xmlns="urn:ietf:params:xml:ns:senml"
  bn="urn:dev:mac:0024beffffe804ff1/"
  bt="1276020076"
  ver="1" bu="A">

  <e n="voltage" u="V" v="120.1" />

  <e n="current" t="-5" v="1.2" />

  <e n="current" t="-4" v="1.30" />

  <e n="current" t="-3" v="0.14e1" />

  <e n="current" t="-2" v="1.5" />

  <e n="current" t="-1" v="1.6" />

  <e n="current" t="0" v="1.7" />

</senml>
```

The RelaxNG schema for the XML is:


```
default namespace = "urn:ietf:params:xml:ns:senml"
namespace rng = "http://relaxng.org/ns/structure/1.0"
```

```
e = element e {
  attribute n { xsd:string }?,
  attribute u { xsd:string }?,
  attribute v { xsd:float }?,
  attribute sv { xsd:string }?,
  attribute bv { xsd:boolean }?,
  attribute s { xsd:decimal }?,
  attribute t { xsd:int }?,
  attribute ut { xsd:int }?,
  p*
}
```

```
senml =
  element senml {
    attribute bn { xsd:string }?,
    attribute bt { xsd:int }?,
    attribute bu { xsd:string }?,
    attribute ver { xsd:int }?,
    e*
  }
```

```
start = senml
```

8. EXI Representation (application/senml-exi)

For efficient transmission of SenML over e.g. a constrained network, Efficient XML Interchange (EXI) can be used. This encodes the XML Schema structure of SenML into binary tags and values rather than ASCII text. An EXI representation of SenML SHOULD be made using the strict schema-mode of EXI. This mode however does not allow tag extensions to the schema, and therefore any extensions will be lost in the encoding. For uses where extensions need to be preserved in EXI, the non-strict schema mode of EXI MAY be used.

The EXI header option MUST be included. An EXI schemaID options MUST be set to the value of "a" indicating the scheme provided in this specification. Future revisions to the schema can change this schemaID to allow for backwards compatibility. When the data will be transported over COAP or HTTP, an EXI Cookie SHOULD NOT be used as it simply makes things larger as is redundant to information provided in the Content-Type header.

The following XSD Schema is generated from the RelaxNG and used for strict schema guided EXI processing.


```

<?xml version="1.0" encoding="UTF-8"?>
<xs:schema xmlns:xs="http://www.w3.org/2001/XMLSchema"
  elementFormDefault="qualified"
  targetNamespace="urn:ietf:params:xml:ns:senml"
  xmlns:ns1="urn:ietf:params:xml:ns:senml">

  <xs:element name="e">
    <xs:complexType>
      <xs:attribute name="n" type="xs:string" minOccurs="0"/>
      <xs:attribute name="u" type="xs:string" minOccurs="0"/>
      <xs:attribute name="v" type="xs:float" minOccurs="0"/>
      <xs:attribute name="sv" type="xs:string" minOccurs="0"/>
      <xs:attribute name="bv" type="xs:boolean" minOccurs="0"/>
      <xs:attribute name="s" type="xs:decimal" minOccurs="0"/>
      <xs:attribute name="t" type="xs:int" minOccurs="0"/>
      <xs:attribute name="ut" type="xs:int" minOccurs="0"/>
    </xs:complexType>
  </xs:element>
  <xs:element name="senml">
    <xs:complexType>
      <xs:sequence>
        <xs:element minOccurs="0" maxOccurs="unbounded" ref="ns1:e"/>
      </xs:sequence>
      <xs:attribute name="bn" type="xs:string"/>
      <xs:attribute name="bt" type="xs:int"/>
      <xs:attribute name="bu" type="xs:string"/>
      <xs:attribute name="ver" type="xs:int"/>
    </xs:complexType>
  </xs:element>
</xs:schema>

```

The following shows a hexdump of the EXI produced from encoding the following XML example. Note that while this example is similar to the first example in [Section 6.1.2](#) in JSON format.

```

<?xml version="1.0" encoding="UTF-8"?>
<senml xmlns="urn:ietf:params:xml:ns:senml"
  bn="urn:dev:ow:10e2073a01080063" >
  <e n="voltage" t="0" v="120.1" u="V" />
  <e n="current" t="0" v="1.2" u="A" />
</senml>

```

Which compresses to the following displayed in hexdump:

```

00000000  a0 30 0d 85 01 d7 57 26  e3 a6 46 57 63 a6 f7 73
00000010  a3 13 06 53 23 03 73 36  13 03 13 03 83 03 03 63
00000020  36 21 2e cd ed 8e 8c 2c  ec a8 00 00 d5 95 88 4c
00000030  02 08 4b 1b ab 93 93 2b  73 a2 00 00 34 14 19 00

```



```
00000040 c0
```

The above example used the bit packed form of EXI but it is also possible to use a byte packed form of EXI which can makes it easier for a simple sensor to produce valid EXI without really implementing EXI. Consider the example of a temperature sensor that produces a value in tenths of degrees Celsius over a range of 0.0 to 55.0. = It would produce XML SenML file such as:

```
<?xml version="1.0" encoding="UTF-8"?>
<senml xmlns="urn:ietf:params:xml:ns:senml"
      bn="urn:dev:ow:10e2073a01080063" >
  <e n="temp" v="23.1" u="degC" />
</senml>
```

The compressed form, using the byte alignment option of EXI, for the above XML is the following:

```
00000000 a00048806c200200 1d75726e3a646576 |..H.l ...urn:dev|
00000010 3a6f773a31306532 3037336130313038 |:ow:10e2073a0108|
00000020 3030363303010674 656d700306646567 |0063...temp..deg|
00000030 430100e701010001 02 |C.....|
```

A small temperature sensor devices that only generates this one EXI file does not really need an full EXI implementation. It can simple hard code the output replacing the one wire device ID starting at byte 0x14 and going to byte 0x23 with it's device ID , and replacing the value "0xe7 0x01" at location 0x33 to 0x34 with the current temperature. The EXI Specification[W3C.REC-exi-20110310] contains the full information on how floating point numbers are represented, but for the purpose of this sensor, the temperature can be converted to an integer in tenths of degrees (231 in this example). EXI stores 7 bits of the integer in each byte with the top bit set to one if there are further bytes. So the first bytes at location 0x33 is set to low 7 bits of the integer temperature in tenths of degrees plus 0x80. In this example $231 \& 0x7F + 0x80 = 0xE7$. The second byte at location 0x34 is set to the integer temperature in tenths of degrees right shifted 7 bits. In this example $231 \gg 7 = 0x01$.

9. Usage Considerations

The measurements support sending both the current value of a sensor as well as the an integrated sum. For many types of measurements, the sum is more useful than the current value. For example, an electrical meter that measures the energy a given computer uses will typically want to measure the cumulative amount of energy used. This is less prone to error than reporting the power each second and

trying to have something on the server side sum together all the power measurements. If the network between the sensor and the meter goes down over some period of time, when it comes back up, the cumulative sum helps reflect what happened while the network was down. A meter like this would typically report a measurement with the units set to watts, but it would put the sum of energy used in the "s" attribute of the measurement. It might optionally include the current power in the "v" attribute.

While the benefit of using the integrated sum is fairly clear for measurements like power and energy, it is less obvious for something like temperature. Reporting the sum of the temperature makes it easy to compute averages even when the individual temperature values are not reported frequently enough to compute accurate averages. Implementors are encouraged to report the cumulative sum as well as the raw value of a given sensor.

Applications that use the cumulative sum values need to understand they are very loosely defined by this specification, and depending on the particular sensor implementation may behave in unexpected ways. Applications should be able to deal with the following issues:

1. Many sensors will allow the cumulative sums to "wrap" back to zero after the value gets sufficiently large.
2. Some sensors will reset the cumulative sum back to zero when the device is reset, loses power, or is replaced with a different sensor.
3. Applications cannot make assumptions about when the device started accumulating values into the sum.

Typically applications can make some assumptions about specific sensors that will allow them to deal with these problems. A common assumption is that for sensors whose measurement values are always positive, the sum should never get smaller; so if the sum does get smaller, the application will know that one of the situations listed above has happened.

10. IANA Considerations

Note to RFC Editor: Please replace all occurrences of "RFC-AAAA" with the RFC number of this specification.

10.1. Units Registry

IANA will create a registry of unit symbols. The primary purpose of this registry is to make sure that symbols uniquely map to give type of measurement. Definitions for many of these units can be found in

[NIST822] and [[BIPM](#)].

In addition to the units in this table, any of the Unified Code for Units of Measure [[UCUM](#)] in case sensitive form (c/s column) can be prepended by the string "UCUM:" and used in SEML.

Symbol	Description	Reference
m	meter	RFC-AAAA
kg	kilogram	RFC-AAAA
s	second	RFC-AAAA
A	ampere	RFC-AAAA
K	kelvin	RFC-AAAA
cd	candela	RFC-AAAA
mol	mole	RFC-AAAA
Hz	hertz	RFC-AAAA
rad	radian	RFC-AAAA
sr	steradian	RFC-AAAA
N	newton	RFC-AAAA
Pa	pascal	RFC-AAAA
J	joule	RFC-AAAA
W	watt	RFC-AAAA
C	coulomb	RFC-AAAA
V	volt	RFC-AAAA
F	farad	RFC-AAAA
Ohm	ohm	RFC-AAAA
S	siemens	RFC-AAAA
Wb	weber	RFC-AAAA
T	tesla	RFC-AAAA
H	henry	RFC-AAAA
Cel	degrees Celsius	RFC-AAAA
lm	lumen	RFC-AAAA
lx	lux	RFC-AAAA
Bq	becquerel	RFC-AAAA
Gy	gray	RFC-AAAA
Sv	sievert	RFC-AAAA
kat	katal	RFC-AAAA
pH	pH acidity	RFC-AAAA
%	Value of a switch. A value of 0.0 indicates the switch is off while 100.0 indicates on.	RFC-AAAA
count	counter value	RFC-AAAA
%RH	Relative Humidity	RFC-AAAA
m2	area	RFC-AAAA
l	volume in liters	RFC-AAAA
m/s	velocity	RFC-AAAA
m/s2	acceleration	RFC-AAAA
l/s	flow rate in liters per second	RFC-AAAA

	W/m2	irradiance		RFC-AAAA	
	cd/m2	luminance		RFC-AAAA	
	Bspl	bel sound pressure level		RFC-AAAA	
	bit/s	bits per second		RFC-AAAA	
	lat	degrees latitude. Assumed to be in WGS84		RFC-AAAA	
		unless another reference frame is known for			
		the sensor.			
	lon	degrees longitude. Assumed to be in WGS84		RFC-AAAA	
		unless another reference frame is known for			
		the sensor.			
	%EL	remaining battery energy level in percents		RFC-AAAA	
	EL	remaining battery energy level in seconds		RFC-AAAA	
	beet/m	Heart rate in beets per minute		RFC-AAAA	
	beets	Cumulative number of heart beats		RFC-AAAA	
+-----+-----+-----+-----+-----+-----+					

New entries can be added to the registration by either Expert Review or IESG Approval as defined in [[RFC5226](#)]. Experts should exercise their own good judgment but need to consider the following guidelines:

1. There needs to be a real and compelling use for any new unit to be added.
2. Units should define the semantic information and be chosen carefully. Implementors need to remember that the same word may be used in different real-life contexts. For example, degrees when measuring latitude have no semantic relation to degrees when measuring temperature; thus two different units are needed.
3. These measurements are produced by computers for consumption by computers. The principle is that conversion has to be easily be done when both reading and writing the media type. The value of a single canonical representation outweighs the convenience of easy human representations or loss of precision in a conversion.
4. Use of SI prefixes such as "k" before the unit is not allowed. Instead one can represent the value using scientific notation such a 1.2e3.
5. For a given type of measurement, there will only be one unit type defined. So for length, meters are defined and other lengths such as mile, foot, light year are not allowed. For most cases, the SI unit is preferred.
6. Symbol names that could be easily confused with existing common units or units combined with prefixes should be avoided. For example, selecting a unit name of "mph" to indicate something that had nothing to do with velocity would be a bad choice, as "mph" is commonly used to mean miles per hour.
7. The following should not be used because the are common SI prefixes: Y, Z, E, P, T, G, M, k, h, da, d, c, n, u, p, f, a, z, y, Ki, Mi, Gi, Ti, Pi, Ei, Zi, Yi.

8. The following units should not be used as they are commonly used to represent other measurements Ky, Gal, dyn, etg, P, St, Mx, G, Oe, Gb, sb, Lmb, ph, Ci, R, RAD, REM, gal, bbl, qt, degF, Cal, BTU, HP, pH, B/s, psi, Torr, atm, at, bar, kWh.
9. The unit names are case sensitive and the correct case needs to be used, but symbols that differ only in case should not be allocated.
10. A number after a unit typically indicates the previous unit raised to that power, and the / indicates that the units that follow are the reciprocal. A unit should have only one / in the name.

10.2. Media Type Registration

The following registrations are done following the procedure specified in [[RFC4288](#)] and [[RFC3023](#)].

Note to RFC Editor: Please replace all occurrences of "RFC-AAAA" with the RFC number of this specification.

10.2.1. senml+json Media Type Registration

Type name: application

Subtype name: senml+json

Required parameters: none

Optional parameters: none

Encoding considerations: Must be encoded as using a subset of the encoding allowed in [[RFC4627](#)]. Specifically, only the ASCII[RFC0020] subset of the UTF-8 characters are allowed. This simplifies implementation of very simple system and does not impose any significant limitations as all this data is meant for machine to machine communications and is not meant to be human readable.

Security considerations: Sensor data can contain a wide range of information ranging from information that is very public, such the outside temperature in a given city, to very private information that requires integrity and confidentiality protection, such as patient health information. This format does not provide any security and instead relies on the transport protocol that carries it to provide security. Given applications need to look at the overall context of how this media type will be used to decide if the security is adequate.

Interoperability considerations: Applications should ignore any JSON

key value pairs that they do not understand. This allows backwards compatibility extensions to this specification. The "ver" field can be used to ensure the receiver supports a minimal level of functionality needed by the creator of the JSON object.

Published specification: RFC-AAAA

Applications that use this media type: The type is used by systems that report electrical power usage and environmental information such as temperature and humidity. It can be used for a wide range of sensor reporting systems.

Additional information:

Magic number(s): none

File extension(s): senml

Macintosh file type code(s): none

Person & email address to contact for further information: Cullen Jennings <fluffy@iii.ca>

Intended usage: COMMON

Restrictions on usage: None

Author: Cullen Jennings <fluffy@iii.ca>

Change controller: IESG

10.2.2. senml+xml Media Type Registration

Type name: application

Subtype name: senml+xml

Required parameters: none

Optional parameters: none

Encoding considerations: TBD

Security considerations: TBD

Interoperability considerations: TBD

Published specification: RFC-AAAA

Applications that use this media type: TBD

Additional information:

Magic number(s): none

File extension(s): senml

Macintosh file type code(s): none

Person & email address to contact for further information: Cullen Jennings <fluffy@iii.ca>

Intended usage: COMMON

Restrictions on usage: None

Author: Cullen Jennings <fluffy@iii.ca>

Change controller: IESG

10.2.3. senml-exi Media Type Registration

Type name: application

Subtype name: senml-exi

Required parameters: none

Optional parameters: none

Encoding considerations: TBD

Security considerations: TBD

Interoperability considerations: TBD

Published specification: RFC-AAAA

Applications that use this media type: TBD

Additional information:

Magic number(s): none

File extension(s): senml

Macintosh file type code(s): none

Person & email address to contact for further information: Cullen Jennings <fluffy@iii.ca>

Intended usage: COMMON

Restrictions on usage: None

Author: Cullen Jennings <fluffy@iii.ca>

Change controller: IESG

10.3. XML Namespace Registration

This document registers the following XML name spaces in the IETF XML registry defined in [[RFC3688](#)].

URI: urn:ietf:params:xml:ns:senml

Registrant Contact: The IESG.

XML: N/A, the requested URIs are XML namespaces

11. Security Considerations

See [Section 12](#). Further discussion of security proprieties can be found in [Section 10.2](#).

12. Privacy Considerations

Sensor data can range from information with almost no security considerations, such as the current temperature in a given city, to highly sensitive medical or location data. This specification provides no security protection for the data but is meant to be used inside another container or transport protocol such as S/MIME or HTTP with TLS that can provide integrity, confidentiality, and authentication information about the source of the data.

13. Acknowledgement

We would like to thank Lisa Dusseault, Joe Hildebrand, Lyndsay Campbell, Martin Thomson, John Klensin, Bjoern Hoehrmann, and Carsten Bormann for their review comments.

14. References

14.1. Normative References

- [BIPM] Bureau International des Poids et Mesures, "The International System of Units (SI)", 8th edition, 2006 .
- [IEEE.754.1985]
Institute of Electrical and Electronics Engineers,
"Standard for Binary Floating-Point Arithmetic",
IEEE Standard 754, August 1985.
- [NIST822] Thompson, A. and B. Taylor, "Guide for the Use of the International System of Units (SI)", NIST Special Publication 811, 2008 Edition .
- [RFC2119] Bradner, S., "Key words for use in RFCs to Indicate Requirement Levels", [BCP 14](#), [RFC 2119](#), March 1997.
- [RFC3023] Murata, M., St. Laurent, S., and D. Kohn, "XML Media Types", [RFC 3023](#), January 2001.
- [RFC3688] Mealling, M., "The IETF XML Registry", [BCP 81](#), [RFC 3688](#), January 2004.
- [RFC4288] Freed, N. and J. Klensin, "Media Type Specifications and Registration Procedures", [BCP 13](#), [RFC 4288](#), December 2005.
- [RFC4627] Crockford, D., "The application/json Media Type for JavaScript Object Notation (JSON)", [RFC 4627](#), July 2006.
- [RFC5226] Narten, T. and H. Alvestrand, "Guidelines for Writing an IANA Considerations Section in RFCs", [BCP 26](#), May 2008.
- [UCUM] Schadow, G. and C. McDonald, "The Unified Code for Units of Measure (UCUM)", Regenstrief Institute and Indiana University School of Informatics .
- [W3C.REC-exi-20110310]
Kamiya, T. and J. Schneider, "Efficient XML Interchange (EXI) Format 1.0", World Wide Web Consortium Recommendation REC-exi-20110310, March 2011,
<<http://www.w3.org/TR/2011/REC-exi-20110310>>.

14.2. Informative References

- [I-D.arkko-core-dev-urn]
Arkko, J., Jennings, C., and Z. Shelby, "Uniform Resource Names for Device Identifiers", [draft-arkko-core-dev-urn-01](#) (work in progress), October 2011.

- [RFC0020] Cerf, V., "ASCII format for network interchange", [RFC 20](#), October 1969.
- [RFC2141] Moats, R., "URN Syntax", [RFC 2141](#), May 1997.
- [RFC3986] Berners-Lee, T., Fielding, R., and L. Masinter, "Uniform Resource Identifier (URI): Generic Syntax", STD 66, [RFC 3986](#), January 2005.
- [RFC4122] Leach, P., Mealling, M., and R. Salz, "A Universally Unique IDentifier (UUID) URN Namespace", [RFC 4122](#), July 2005.
- [RFC5952] Kawamura, S. and M. Kawashima, "A Recommendation for IPv6 Address Text Representation", [RFC 5952](#), August 2010.
- [RFC6690] Shelby, Z., "CoRE Link Format", [RFC 6690](#), June 2012.
- [RFC7252] Shelby, Z., Hartke, K., and C. Bormann, "Constrained Application Protocol (CoAP)", [RFC 7252](#), June 2013.
- [WADL] Hadley, M., "Web Application Description Language (WADL)", 2009, <<http://java.net/projects/wadl/sources/svn/content/trunk/www/wadl20090202.pdf>>.

Authors' Addresses

Cullen Jennings
Cisco
170 West Tasman Drive
San Jose, CA 95134
USA

Phone: +1 408 421-9990
Email: fluffy@cisco.com

Zach Shelby
ARM
150 Rose Orchard
San Jose 95134
FINLAND

Phone: +1-408-203-9434
Email: zach.shelby@arm.com

Jari Arkko
Ericsson
Jorvas 02420
Finland

Email: jari.arkko@piuha.net