

Network Working Group
Internet-Draft
Intended Status: Standards Track
Expires: April 22, 2013

M. Chandramouli
Cisco Systems, Inc.
B. Schoening
Independent Consultant
J. Quittek
T. Dietz
NEC Europe Ltd.
B. Claise
Cisco Systems, Inc.
October 22, 2012

Power and Energy Monitoring MIB
draft-ietf-eman-energy-monitoring-mib-04

Status of this Memo

This Internet-Draft is submitted to IETF in full conformance with the provisions of BCP 78 and BCP 79.

Internet-Drafts are working documents of the Internet Engineering Task Force (IETF), its areas, and its working groups. Note that other groups may also distribute working documents as Internet-Drafts.

Internet-Drafts are draft documents valid for a maximum of six months and may be updated, replaced, or obsoleted by other documents at any time. It is inappropriate to use Internet-Drafts as reference material or to cite them other than as "work in progress."

The list of current Internet-Drafts can be accessed at <http://www.ietf.org/ietf/lid-abstracts.txt>

The list of Internet-Draft Shadow Directories can be accessed at <http://www.ietf.org/shadow.html>

This Internet-Draft will expire on April 2013.

<Claise, et. Al>

Expires April 22, 2013

[Page 1]

Copyright (c) 2011 IETF Trust and the persons identified as the document authors. All rights reserved.

This document is subject to BCP 78 and the IETF Trust's Legal Provisions Relating to IETF Documents (<http://trustee.ietf.org/license-info>) in effect on the date of publication of this document. Please review these documents carefully, as they describe your rights and restrictions with respect to this document. Code Components extracted from this document must include Simplified BSD License text as described in Section 4.e of the Trust Legal Provisions and are provided without warranty as described in the Simplified BSD License.

Abstract

This document defines a subset of the Management Information Base (MIB) for power and energy monitoring of devices.

Conventions used in this document

The key words "MUST", "MUST NOT", "REQUIRED", "SHALL", "SHALL NOT", "SHOULD", "SHOULD NOT", "RECOMMENDED", "NOT RECOMMENDED", "MAY", and "OPTIONAL" in this document are to be interpreted as described in RFC 2119 [RFC2119].

Table of Contents

1. Introduction.....	3
2. The Internet-Standard Management Framework.....	4
3. Use Cases.....	4
4. Terminology.....	5
5. Architecture Concepts Applied to the MIB Module.....	6
5.1. Energy Object Information.....	13
5.2. Power State.....	14
5.2.1. Power State Set.....	15
5.2.2. IEEE1621 Power State Set.....	15
5.2.3. DMTF Power State Set.....	15
5.2.4. EMAN Power State Set.....	17
5.3. Energy Object Usage Information.....	19
5.4. Optional Power Usage Characteristics.....	20
5.5. Optional Energy Measurement.....	21

Internet-Draft	<Power and Energy Monitoring MIB>	October 2012
5.6.	Fault Management.....	25
6.	Discovery.....	26
7.	Link with the other IETF MIBs.....	27
7.1.	Link with the ENTITY-MIB and the ENTITY-SENSOR MIB..	27
7.2.	Link with the ENTITY-STATE MIB.....	28
7.3.	Link with the POWER-OVER-ETHERNET MIB.....	28
7.4.	Link with the UPS MIB.....	29
7.5.	Link with the LLDP and LLDP-MED MIBs.....	30
8.	Implementation Scenario.....	31
9.	Structure of the MIB.....	33
10.	MIB Definitions.....	34
11.	Security Considerations.....	74
12.	IANA Considerations.....	75
12.1.	IANA Considerations for the MIB Modules.....	75
12.2.	IANA Registration of new Power State Set.....	76
12.2.1.	IANA Registration of the IEEE1621 Power State Set	76
12.2.2.	IANA Registration of the DMTF Power State Set....	77
12.2.3.	IANA Registration of the EMAN Power State Set....	77
12.3.	Updating the Registration of Existing Power State Sets.....	77
12.	Contributors.....	78
13.	Acknowledgment.....	78
14.	Open Issues.....	78
15.	References.....	79
15.2.	Normative References.....	79
15.3.	Informative References.....	79

1. Introduction

This document defines a subset of the Management Information Base (MIB) for use in energy management of devices within or connected to communication networks. The MIB modules in this document are designed to provide a model for energy management, which includes monitoring for power state and energy consumption of networked elements. This MIB takes into account the Energy Management Framework [EMAN-FMWK], which in turn, is based on the Requirements for Energy Management [EMAN-REQ].

Energy management is applicable to devices in communication networks. Target devices for this specification include (but are not limited to): routers, switches, Power over Ethernet (PoE) endpoints, protocol gateways for building management systems, intelligent meters, home energy gateways, hosts and servers, sensor proxies, etc. Target devices and the use cases

Internet-Draft <Power and Energy Monitoring MIB> October 2012
for Energy Management are discussed in Energy Management
Applicability Statement [EMAN-AS].

Where applicable, device monitoring extends to the individual components of the device and to any attached dependent devices. For example: A device can contain components that are independent from a power-state point of view, such as line cards, processor cards, hard drives. A device can also have dependent attached devices, such as a switch with PoE endpoints or a power distribution unit with attached endpoints.

Devices and their sub-components may be characterized by the power-related attributes of a physical entity present in the ENTITY-MIB, even though the ENTITY-MIB compliance is not a requirement due to the variety and broad base of devices concerned with energy management.

2. The Internet-Standard Management Framework

For a detailed overview of the documents that describe the current Internet-Standard Management Framework, please refer to section 7 of RFC 3410 [RFC3410].

Managed objects are accessed via a virtual information store, termed the Management Information Base or MIB. MIB objects are generally accessed through the Simple Network Management Protocol (SNMP). Objects in the MIB are defined using the mechanisms defined in the Structure of Management Information (SMI). This memo specifies MIB modules that are compliant to SMIv2, which is described in STD 58, RFC 2578 [RFC2578], STD 58, RFC 2579 [RFC2579] and STD 58, RFC 2580 [RFC2580].

3. Use Cases

Requirements for power and energy monitoring for networking devices are specified in [EMAN-REQ]. The requirements in [EMAN-REQ] cover devices typically found in communications networks, such as switches, routers, and various connected endpoints. For a power monitoring architecture to be useful, it should also apply to facility meters, power distribution units, gateway proxies for commercial building control, home automation devices, and devices that interface with the utility and/or smart grid. Accordingly, the scope of the MIB modules in this document is broader than that specified in [EMAN-REQ]. Several use cases for Energy Management have been identified in the

Internet-Draft <Power and Energy Monitoring MIB> October 2012
"Energy Management (EMAN) Applicability Statement" [EMAN-AS]. An
illustrative example scenario is presented in Section 8.

4. Terminology

Please refer to [EMAN-FMWK] for the definitions of the
following terminology used in this draft.

Device

Component

Energy Management

Energy Management System (EnMS)

ISO Energy Management System

Energy

Power

Demand

Power Characteristics

Electrical Equipment

Non-Electrical Equipment (Mechanical Equipment)

Energy Object

Electrical Energy Object

Non-Electrical Energy Object

Energy Monitoring

Energy Control

Provide Energy:

Receive Energy:

Power Interface

Power Outlet

Energy Management Domain

Energy Object Identification

Energy Object Context

Energy Object Relationship

Aggregation Relationship

Metering Relationship

Power Source Relationship

Proxy Relationship

Energy Object Parent

Energy Object Child

Power State

Power State Set

Nameplate Power

5. Architecture Concepts Applied to the MIB Module

This section describes the concepts specified in the Energy Management Framework [EMAN-FMWK] that pertain to power usage, with specific information related to the MIB module specified in this document. This subsection maps to the section "Architecture High Level Concepts" in the Power Monitoring Architecture [EMAN-FMWK].

The Energy Monitoring MIB has 2 independent MIB modules. The first MIB module energyObjectMib is focused on measurement of power and energy. The second MIB module powerCharMIB is focused on Power Characteristics measurements.

The energyObjectMib MIB module consists of four tables. The first table eoPowerTable is indexed by entPhysicalIndex. The second table eoPowerStateTable indexed by entPhysicalIndex,

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 and eoPowerStateIndex. The eoEnergyParametersTable is indexed
 by eoEnergyParametersIndex. The eoEnergyTable is indexed by
 eoEnergyParametersIndex and eoEnergyCollectionStartTime.

```

eoMeterCapabilitiesTable(1)
|
+--- eoMeterCapabilitiesEntry(1) [entPhysicalIndex]
|   |
|   +---r-n BITS                    eoMeterCapability
|
|
eoPowerTable(1)
|
+---eoPowerEntry(1) [entPhysicalIndex]
|   |
|   +---r-n Integer32                eoPower(1)
|   +---r-n Integer32                eoPowerNamePlate(2)
|   +---r-n UnitMultiplier           eoPowerUnitMultiplier(3)
|   +---r-n Integer32                eoPowerAccuracy(4)
|   +---r-n INTEGER                  eoMeasurementCaliber(5)
|   +---r-n INTEGER                  eoPowerCurrentType(6)
|   +---r-n INTEGER                  eoPowerOrigin(7)
|   +---r-n Integer32                eoPowerAdminState(8)
|   +---r-n Integer32                eoPowerOperState(9)
|   +---r-n OwnerString              eoPowerStateEnterReason(10)
|
|
+---eoPowerStateTable(2)
|   +---eoPowerStateEntry(1)
|       |
|       +---[entPhysicalIndex,
|           |
|           +---eoPowerStateIndex]
|       |
|       +--- --n IANAPowerStateSet    eoPowerStateIndex(1)
|       +---r-n Integer32             eoPowerStateMaxPower (2)
|       +---r-n UnitMultiplier
|           |
|           +---eoPowerStatePowerUnitMultiplier (3)
|       +---r-n TimeTicks              eoPowerStateTotalTime(4)
|       +---r-n Counter32              eoPowerStateEnterCount(5)
|
|
+eoEnergyParametersTable(1)
+---eoEnergyParametersEntry(1) [eoEnergyParametersIndex]
|
|
|   +--- --n PhysicalIndex            eoEnergyObjectIndex (1)
|   +---r-n Integer32                 eoEnergyParametersIndex (2)
|   +---r-n TimeInterval

```



```

|               eoEnergyParametersIntervalLength (3)
|   +--- r-n Integer32
|               eoEnergyParametersIntervalNumber (4)
|   +--- r-n Integer32
|               eoEnergyParametersIntervalMode (5)
|   +--- r-n TimeInterval
|               eoEnergyParametersIntervalWindow (6)
|   +--- r-n Integer32
|               eoEnergyParametersSampleRate (7)
|   +--- r-n RowStatus   eoEnergyParametersStatus (8)
|
+eoEnergyTable (1)
+----eoEnergyEntry(1) [ eoEnergyParametersIndex,
eoEnergyCollectionStartTime]
|
|   +--- r-n TimeTicks      eoEnergyCollectionStartTime (1)
|   +--- r-n Integer32      eoEnergyConsumed (2)
|   +--- r-n Integer32      eoEnergyProduced (3)
|   +--- r-n Integer32      eoEnergyNet (4)
|   +--- r-n UnitMultiplier
|               eoEnergyUnitMultiplier (5)
|   +--- r-n Integer32      eoEnergyAccuracy(6)
|   +--- r-n Integer32      eoEnergyMaxConsumed (7)
|   +--- r-n Integer32      eoEnergyMaxProduced (8)
|   +--- r-n TimeTicks
|               eoEnergyDiscontinuityTime(9)
|   +--- r-n RowStatus      eoEnergyParametersStatus (10)

```

The powerCharacteristicsMIB consists of four tables.
 eoACPwrCharacteristicsTable is indexed by entPhysicalIndex.
 eoACPwrCharacteristicsPhaseTable is indexed by entPhysicalIndex
 and eoPhaseIndex. eoACPwrCharacteristicsWyePhaseTable and
 eoACPwrCharacteristicsDelPhaseTable are indexed by
 entPhysicalIndex and eoPhaseIndex.

```

eoACPwrCharacteristicsTable (1)
|
+----eoACPwrCharacteristicsEntry (1) [ entPhysicalIndex]
|
|   +----r-n INTEGER      eoACPwrCharacteristicsConfiguration
(1)
|   +--- r-n Integer32     eoACPwrCharacteristicsAvgVoltage (2)
|   +--- r-n Integer32     eoACPwrCharacteristicsAvgCurrent (3)
|   +--- r-n Integer32     eoACPwrCharacteristicsFrequency (4)
|   +--- r-n UnitMultiplier
|               eoACPwrCharacteristicsPowerUnitMultiplier (5)

```




```

Internet-Draft    <Power and Energy Monitoring MIB>   October 2012
|
|      +-- r-n Integer32
|      |      eoACPwrCharacteristicsWyePhaseToNeutralVoltage
(1)
|
|      +-- r-n Integer32
|      |      eoACPwrCharacteristicsWyePhaseCurrent (2)
|      +-- r-n Integer32
|      |      eoACPwrCharacteristicsWyeThdPhaseToNeutralVoltage
(3)
|
|      .

```

A UML representation of the MIB objects in the two MIB modules are energyObjectMib and powerCharacteristicsMIB are presented.








Figure 1:UML diagram for energyObjectMib



(*) Link with the ENTITY-MIB

V





V





↓
v






Figure 2: UML diagram for the powerCharacteristicsMIB

(*) Link with the ENTITY-MIB

5.1. Energy Object Information

Refer to the "Energy Object Information" section in [EMAN-FMWK] for background information. An energy aware device is considered as an instance of a Energy Object as defined in the [EMAN-FMWK].

Internet-Draft <Power and Energy Monitoring MIB> October 2012
The Energy Object identity information is specified in the MIB ENERGY-AWARE-MIB module [EMAN-AWARE-MIB] primary table, i.e. the eoTable. In this table, every Energy Object SHOULD have a printable name eoName, and MUST HAVE a unique Energy Object index entPhysicalUUID and entPhysicalIndex. The ENERGY-AWARE-MIB module returns the relationship (parent/child) between Energy Objects. There are several possible relationships between Parent and Child as defined in [EMAN-AWARE-MIB] such as MeteredBy, PoweredBy, AggregatedBy and ProxyedBy.

5.2. Power State

Refer to the "Power States" section in [EMAN-FMWK] for background information.

An Energy Object may have energy conservation modes called Power States. Between the ON and OFF states of a device, there can be several intermediate energy saving modes. Those energy saving modes are called as Power States.

Power States, which represent universal states of power management of an Energy Object, are specified by the eoPowerState MIB object. The actual Power State is specified by the eoPowerOperState MIB object, while the eoPowerAdminState MIB object specifies the Power State requested for the Energy Object. The difference between the values of eoPowerOperState and eoPowerAdminState can be attributed that the Energy Object is busy transitioning from eoPowerAdminState into the eoPowerOperState, at which point it will update the content of eoPowerOperState. In addition, the possible reason for change in Power State is reported in eoPowerStateEnterReason. Regarding eoPowerStateEnterReason, management stations and Energy Objects should support any format of the owner string dictated by the local policy of the organization. It is suggested that this name contain at least the reason for the transition change, and one or more of the following: IP address, management station name, network manager's name, location, or phone number.

The MIB objects eoPowerOperState, eoPowerAdminState, and eoPowerStateEnterReason are contained in the eoPowerTable MIB table.

The eoPowerStateTable table enumerates the maximum power usage in watts, for every single supported Power State of each Power State Set supported by the Energy Object. In addition,

Internet-Draft <Power and Energy Monitoring MIB> October 2012
PowerStateTable provides additional statistics:
eoPowerStateEnterCount, the number of times an entity has
visited a particular Power State, and eoPowerStateTotalTime, the
total time spent in a particular Power State of an Energy
Object.

5.2.1. Power State Set

There are several standards and implementations of Power State
Sets. A Energy Object can support one or multiple Power State
Set implementation(s) concurrently.

There are currently three Power State Sets advocated:

- unknown(0)
- IEEE1621(256) - [IEEE1621]
- DMTF(512) - [DMTF]
- EMAN(1024) - [EMAN-MONITORING-MIB]

The respective specific states related to each Power State Set
are specified in the following sections. The guidelines for
addition of new Power State Sets have been specified in the IANA
Considerations Section.

5.2.2. IEEE1621 Power State Set

The IEEE1621 Power State Set [IEEE1621] consists of 3
rudimentary states : on, off or sleep.

- on(0) - The device is fully On and all features of the
device are in working mode.
- off(1) - The device is mechanically switched off and does
not consume energy.
- sleep(2) - The device is in a power saving mode, and some
features may not be available immediately.

The Textual Convention IANAPowerStateSet provides the proposed
numbering of the Power States within the IEEE1621 Power State
Set.

5.2.3. DMTF Power State Set

DMTF [DMTF] standards organization has defined a power profile
standard based on the CIM (Common Information Model) model that
consists of 15 power states ON (2), SleepLight (3), SleepDeep

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 (4), Off-Hard (5), Off-Soft (6), Hibernate(7), PowerCycle Off-Soft (8), PowerCycle Off-Hard (9), MasterBus reset (10), Diagnostic Interrupt (11), Off-Soft-Graceful (12), Off-Hard Graceful (13), MasterBus reset Graceful (14), Power-Cycle Off-Soft Graceful (15), PowerCycle-Hard Graceful (16). DMTF standard is targeted for hosts and computers. Details of the semantics of each Power State within the DMTF Power State Set can be obtained from the DMTF Power State Management Profile specification [DMTF].

DMTF power profile extends ACPI power states. The following table provides a mapping between DMTF and ACPI Power State Set:

DMTF Power State	ACPI Power State
Reserved(0)	
Reserved(1)	
ON (2)	G0-S0
Sleep-Light (3)	G1-S1 G1-S2
Sleep-Deep (4)	G1-S3
Power Cycle (Off-Soft) (5)	G2-S5
Off-hard (6)	G3
Hibernate (Off-Soft) (7)	G1-S4
Off-Soft (8)	G2-S5
Power Cycle (Off-Hard) (9)	G3
Master Bus Reset (10)	G2-S5
Diagnostic Interrupt (11)	G2-S5
Off-Soft Graceful (12)	G2-S5
Off-Hard Graceful (13)	G3
MasterBus Reset Graceful (14)	G2-S5
Power Cycle off-soft Graceful (15)	G2-S5

```

-----
| Power Cycle off-hard Graceful (16)| G3          |
-----

```

Figure 3: DMTF and ACPI Powe State Set Mapping

The Textual Convention IANAPowerStateSet contains the proposed numbering of the Power States within the DMTF Power State Set.

5.2.4. EMAN Power State Set

The EMAN Power State Set represents an attempt for a uniform standard approach to model the different levels of power consumption of a device. The EMAN Power States are an expansion of the basic Power States as defined in IEEE1621 that also incorporate the Power States defined in ACPI and DMTF. Therefore, in addition to the non-operational states as defined in ACPI and DMTF standards, several intermediate operational states have been defined.

There are twelve Power States, that expand on IEEE1621 on, sleep and off. The expanded list of Power States are divided into six operational states, and six non-operational states. The lowest non-operational state is 1 and the highest is 6. Each non-operational state corresponds to an ACPI state [ACPI] corresponding to Global and System states between G3 (hard-off) and G1 (sleeping). For Each operational state represent a performance state, and may be mapped to ACPI states P0 (maximum performance power) through P5 (minimum performance and minimum power).

An Energy Object may have fewer Power States than twelve and would then map several policy states to the same power state. Energy Object with more than twelve states, would choose which twelve to represent as power policy states.

In each of the non-operational states (from mechoff(1) to ready(6)), the Power State preceding it is expected to have a lower power consumption and a longer delay in returning to an operational state:

IEEE1621 Power(off):

```

    mechoff(1) : An off state where no entity features are
                  available. The entity is unavailable.
                  No energy is being consumed and the power

```

softoff(2) : Similar to mechoff(1), but some components remain powered or receive trace power so that the entity can be awakened from its off state. In softoff(2), no context is saved and the device typically requires a complete boot when awakened. This corresponds to ACPI state G2.

IEEE1621 Power(sleep)

hibernate(3): No entity features are available. The entity may be awakened without requiring a complete boot, but the time for availability is longer than sleep(4). An example for state hibernate(3) is a save-to-disk state where DRAM context is not maintained. Typically, energy consumption is zero or close to zero. This corresponds to state G1, S4 in ACPI.

sleep(4) : No entity features are available, except for out-of-band management, for example wake-up mechanisms. The time for availability is longer than standby(5). An example for state sleep(4) is a save-to-RAM state, where DRAM context is maintained. Typically, energy consumption is close to zero. This corresponds to state G1, S3 in ACPI.

standby(5) : No entity features are available, except for out-of-band management, for example wake-up mechanisms. This mode is analogous to cold-standby. The time for availability is longer than ready(6). For example, the processor context is not maintained. Typically, energy consumption is close to zero. This corresponds to state G1, S2 in ACPI.

ready(6) : No entity features are available, except for out-of-band management, for example wake-up mechanisms. This mode is analogous to hot-standby. The entity can

Internet-Draft <Power and Energy Monitoring MIB> October 2012
be quickly transitioned into an operational state. For example, processors are not executing, but processor context is maintained. This corresponds to state G1, S1 in ACPI.

IEEE1621 Power(on):

lowMinus(7) : Indicates some entity features may not be available and the entity has selected measures/options to provide less than low(8) usage. This corresponds to ACPI State G0. This includes operational states lowMinus(7) to full(12).

low(8) : Indicates some features may not be available and the entity has taken measures or selected options to provide less than mediumMinus(9) usage.

mediumMinus(9): Indicates all entity features are available but the entity has taken measures or selected options to provide less than medium(10) usage.

medium(10) : Indicates all entity features are available but the entity has taken measures or selected options to provide less than highMinus(11) usage.

highMinus(11): Indicates all entity features are available and power usage is less than high(12).

high(12) : Indicates all entity features are available and the entity is consuming the highest power.

The Textual Convention IANAPowerStateSet contains the proposed numbering of the Power States within the EMAN Power State Set.

5.3. Energy Object Usage Information

Refer to the "Energy Object Usage Measurement" section in [EMAN-FMWK] for background information.

For an Energy Object, power usage is reported using eoPower. The magnitude of measurement is based on the eoPowerUnitMultiplier MIB variable, based on the UnitMultiplier Textual Convention (TC). Power measurement magnitude should conform to the IEC 62053-21 [IEC.62053-21] and IEC 62053-22 [IEC.62053-22] definition of unit multiplier for the SI (System International) units of measure. Measured values are represented in SI units obtained by BaseValue * 10 raised to the power of the scale.

For example, if current power usage of an Energy Object is 3, it could be 3 W, 3 mW, 3 KW, or 3 MW, depending on the value of eoPowerUnitMultiplier. Note that other measurements throughout the two MIB modules in this document use the same mechanism, including eoPowerStatePowerUnitMultiplier, eoEnergyUnitMultiplier, and eoACPwrCharacteristicsPowerUnitMultiplier.

In addition to knowing the usage and magnitude, it is useful to know how a eoPower measurement was obtained. An NMS can use this to account for the accuracy and nature of the reading between different implementations. For this eoPowerOrigin describes whether the measurements were made at the device itself or from a remote source. The eoPowerMeasurementCaliber describes the method that was used to measure the power and can distinguish actual or estimated values. There may be devices in the network, which may not be able to measure or report power consumption. For those devices, the object eoPowerMeasurementCaliber shall report that measurement mechanism is "unavailable" and the eoPower measurement shall be "0".

The nameplate power rating of an Energy Object is specified in eoPowerNameplate MIB object.

5.4. Optional Power Usage Characteristics

Refer to the "Optional Power Usage Characteristics" section in [EMAN-FMWK] for background information.

The optional powerCharacteristicsMIB MIB module can be implemented to further describe power usage characteristics measurement. The powerCharacteristicsMIB MIB module adheres closely to the IEC 61850 7-2 standard to describe AC measurements.

The powerCharacteristicsMIB MIB module contains a primary table, the eoACPwrCharacteristicsTable table, that defines power characteristics measurements for supported entPhysicalIndex entities, as a sparse extension of the eoPowerTable (with entPhysicalIndex as primary index). This eoACPwrCharacteristicsTable table contains such information as the configuration (single phase, DEL 3 phases, WYE 3 phases), voltage, frequency, power accuracy, total active/reactive power/apparent power, amperage, and voltage.

In case of 3-phase power, the eoACPwrCharacteristicsPhaseTable additional table is populated with Power Characteristics measurements per phase (so double indexed by the entPhysicalIndex and eoPhaseIndex). This table, which describes attributes common to both WYE and DEL configurations, contains the average current, active/reactive/apparent power, power factor, and impedance.

In case of 3-phase power with a DEL configuration, the eoACPwrCharacteristicsDelPhaseTable table describes the phase-to-phase power characteristics measurements, i.e., voltage and current.

In case of 3-phase power with a Wye configuration, the eoACPwrCharacteristicsWyePhaseTable table describes the phase-to-neutral power characteristics measurements, i.e., voltage and current.

5.5. Optional Energy Measurement

Refer to the "Optional Energy and demand Measurement" section in [EMAN-FMWK] for the definition and terminology information.

It is relevant to measure energy when there are actual power measurements from an Energy Object, and not when the power measurement is assumed or predicted as specified in the description clause of the object eoPowerMeasurementCaliber.

Two tables are introduced to characterize energy measurement of an Energy Object: eoEnergyTable and eoEnergyParametersTable. Both energy and demand information can be represented via the eoEnergyTable. Energy information will be an accumulation with no interval. Demand information can be represented. The eoEnergyParametersTable consists of the parameters defining eoEnergyParametersIndex, an index of that specifies the setting for collection of energy measurements for an Energy Object, eoEnergyObjectIndex, linked to the entPhysicalIndex of the

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 Energy Object, the duration of measurement intervals in seconds,
 (eoEnergyParametersIntervalLength), the number of successive
 intervals to be stored in the eoEnergyTable,
 (eoEnergyParametersIntervalNumber), the type of measurement
 technique (eoEnergyParametersIntervalMode), and a sample rate
 used to calculate the average (eoEnergyParametersSampleRate).
 Judicious choice of the sampling rate will ensure accurate
 measurement of energy while not imposing an excessive polling
 burden.

There are three eoEnergyParametersIntervalMode types used for
 energy measurement collection: period, sliding, and total. The
 choices of the the three different modes of collection are based
 on IEC standard 61850-7-4. Note that multiple
 eoEnergyParametersIntervalMode types MAY be configured
 simultaneously. It is important to note that for a given Energy
 Object, multiple modes (periodic, total, sliding window) of
 energy measurement collection can be configured with the use of
 eoEnergyParametersIndex. However, simultaneous measurement in
 multiple modes for a given Energy Object depends on the Energy
 Object capability.

These three eoEnergyParametersIntervalMode types are illustrated
 by the following three figures, for which:

- The horizontal axis represents the current time, with the
 symbol <--- L ---> expressing the
 eoEnergyParametersIntervalLength, and the
 eoEnergyCollectionStartTime is represented by S1, S2, S3, S4,
 ..., Sx where x is the value of
 eoEnergyParametersIntervalNumber.
- The vertical axis represents the time interval of sampling and
 the value of eoEnergyConsumed can be obtained at the end of the
 sampling period. The symbol ===== denotes the duration of
 the sampling period.




Figure 4 : Period eoEnergyParametersIntervalMode

A eoEnergyParametersIntervalMode type of 'period' specifies non-overlapping periodic measurements. Therefore, the next eoEnergyCollectionStartTime is equal to the previous eoEnergyCollectionStartTime plus eoEnergyParametersIntervalLength. $S2=S1+L$; $S3=S2+L$, ...





Figure 5 : Sliding eoEnergyParametersIntervalMode

A eoEnergyParametersIntervalMode type of 'sliding' specifies overlapping periodic measurements.



A `eoEnergyParametersIntervalMode` type of 'total' specifies a continuous measurement since the last reset. The value of `eoEnergyParametersIntervalNumber` should be (1) one and `eoEnergyParametersIntervalLength` is ignored.

The `eoEnergyTable` consists of energy measurements in `eoEnergyConsumed`, `eoEnergyProduced` and `eoEnergyNet`, the units of the measured energy `eoEnergyUnitMultiplier`, and the maximum observed energy within a window, `eoEnergyMaxConsumed`, `eoEnergyMaxProduced`.

The following example illustrates the `eoEnergyTable` and `eoEnergyParametersTable`:

The indices for the `eoEnergyTable` are `eoEnergyParametersIndex` which identifies the index for the setting of energy measurement collection Energy Object, and `eoEnergyCollectionStartTime`, which

Internet-Draft <Power and Energy Monitoring MIB> October 2012
denotes the start time of the energy measurement interval based on sysUpTime [RFC3418]. The value of eoEnergyConsumed is the measured energy consumption over the time interval specified (eoEnergyParametersIntervalLength) based on the Energy Object internal sampling rate (eoEnergyParametersSampleRate). While choosing the values for the eoEnergyParametersIntervalLength and eoEnergyParametersSampleRate, it is recommended to take into consideration either the network element resources adequate to process and store the sample values, and the mechanism used to calculate the eoEnergyConsumed. The units are derived from eoEnergyUnitMultiplier. For example, eoEnergyConsumed can be "100" with eoEnergyUnitMultiplier equal to 0, the measured energy consumption of the Energy Object is 100 watt-hours. The eoEnergyMaxConsumed is the maximum energy observed and that can be "150 watt-hours".

The eoEnergyTable has a buffer to retain a certain number of intervals, as defined by eoEnergyParametersIntervalNumber. If the default value of "10" is kept, then the eoEnergyTable contains 10 energy measurements, including the maximum.

Here is a brief explanation of how the maximum energy can be calculated. The first observed energy measurement value is taken to be the initial maximum. With each subsequent measurement, based on numerical comparison, maximum energy may be updated. The maximum value is retained as long as the measurements are taking place. Based on periodic polling of this table, an NMS could compute the maximum over a longer period, i.e. a month, 3 months, or a year.

5.6. Fault Management

[EMAN-REQ] specifies requirements about Power States such as "the current power state" , "the time of the last state change", "the total time spent in each state", "the number of transitions to each state" etc. Some of these requirements are fulfilled explicitly by MIB objects such as eoPowerOperState, eoPowerStateTotalTime and eoPowerStateEnterCount. Some of the other requirements are met via the SNMP NOTIFICATION mechanism. eoPowerStateChange SNMP notification which is generated when the value(s) of ,eoPowerStateIndex, eoPowerOperState, eoPowerAdminState have changed.

It is foreseen that most Energy Objects will require the implementation of the ENERGY-AWARE MIB [EMAN-AWARE-MIB] as a prerequisite for this MIB module. In such a case, eoPowerTable of the EMAN-MON-MIB is a sparse extension of the eoTable of ENERGY-AWARE-MIB. Every Energy Object MUST implement entPhysicalIndex, entPhysicalUUID and entPhysicalName from the ENTITY-MIB [EMAN-ENTITY]. As the primary index for the Energy Object, entPhysicalIndex is used.

The NMS must first poll the ENERGY-AWARE-MIB module [EMAN-AWARE-MIB], if available, in order to discover all the Energy Objects and the relationships between those (notion of Parent/Child). In the ENERGY-AWARE-MIB module tables, the Energy Objects are indexed by the entPhysicalIndex.

If an implementation of the ENERGY-AWARE-MIB module is available in the local SNMP context, for the same Energy Object, the entPhysicalIndex value (EMAN-AWARE-MIB) shall be used. The entPhysicalIndex characterizes the Energy Object in the energyObjectMib and the powerCharacteristicsMIB MIB modules (this document).

From there, the NMS must poll the eoPowerStateTable (specified in the energyObjectMib module in this document), which enumerates, amongst other things, the maximum power usage. As the entries in eoPowerStateTable table are indexed by the Energy Object (entPhysicalIndex), by the Power State Set (eoPowerStateIndex), the maximum power usage is discovered per Energy Object, and the power usage per Power State of the Power State Set. In other words, polling the eoPowerStateTable allows the discovery of each Power State within every Power State Set supported by the Energy Object.

If the Energy Object is an Aggregator or a Proxy, the MIB module would be populated with the Energy Object Parent and Children information, which have their own Energy Object index value (entPhysicalIndex). However, the parent/child relationship must be discovered thanks to the ENERGY-AWARE-MIB module.

Finally, the NMS can monitor the power characteristics thanks to the powerCharacteristicsMIB MIB module, which reuses the entPhysicalIndex to index the Energy Object.

7.1. Link with the ENTITY-MIB and the ENTITY-SENSOR MIB

RFC 4133 [RFC4133] defines the ENTITY-MIB module that lists the physical entities of a networking device (router, switch, etc.) and those physical entities indexed by entPhysicalIndex. From an energy-management standpoint, the physical entities that consume or produce energy are of interest.

RFC 3433 [RFC3433] defines the ENTITY-SENSOR MIB module that provides a standardized way of obtaining information (current value of the sensor, operational status of the sensor, and the data units precision) from sensors embedded in networking devices. Sensors are associated with each index of entPhysicalIndex of the ENTITY-MIB [RFC4133]. While the focus of the Power and Energy Monitoring MIB is on measurement of power usage of networking equipment indexed by the ENTITY-MIB, this MIB proposes a customized power scale for power measurement and different power state states of networking equipment, and functionality to configure the power state states.

When this MIB module is used to monitor the power usage of devices like routers and switches, the ENTITY-MIB and ENTITY-SENSOR MIB SHOULD be implemented. In such cases, the Energy Objects are modeled by the entPhysicalIndex through the entPhysicalEntity MIB object specified in the eoTable in the ENERGY-AWARE-MIB MIB module [EMAN-AWARE-MIB].

However, the ENTITY-SENSOR MIB [RFC3433] does not have the ANSI C12.x accuracy classes required for electricity (i.e., 1%, 2%, 0.5% accuracy classes). Indeed, entPhySensorPrecision [RFC3433] represents "The number of decimal places of precision in fixed-point sensor values returned by the associated entPhySensorValue object". The ANSI and IEC Standards are used for power measurement and these standards require that we use an accuracy class, not the scientific-number precision model specified in RFC3433. The eoPowerAccuracy MIB object models this accuracy. Note that eoPowerUnitMultiplier represents the scale factor per IEC 62053-21 [IEC.62053-21] and IEC 62053-22 [IEC.62053-22], which is a more logical representation for power measurements (compared to entPhySensorScale), with the mantissa and the exponent values $X * 10 ^ Y$.

Power measurements specifying the qualifier 'UNITS' for each measured value in watts are used in the LLDP-EXT-MED-MIB, POE

Internet-Draft <Power and Energy Monitoring MIB> October 2012
[RFC3621], and UPS [RFC1628] MIBs. The same 'UNITS' qualifier
is used for the power measurement values.

One cannot assume that the ENTITY-MIB and ENTITY-SENSOR MIB are implemented for all Energy Objects that need to be monitored. A typical example is a converged building gateway, monitoring several other devices in the building, doing the proxy between SNMP and a protocol like BACNET. Another example is the home energy controller. In such cases, the eoPhysicalEntity value contains the zero value, thanks to PhysicalIndexOrZero textual convention.

The eoPower is similar to entPhySensorValue [RFC3433] and the eoPowerUnitMultiplier is similar to entPhySensorScale.

7.2. Link with the ENTITY-STATE MIB

For each entity in the ENTITY-MIB [RFC4133], the ENTITY-STATE MIB [RFC4268] specifies the operational states (entStateOper: unknown, enabled, disabled, testing), the alarm (entStateAlarm: unknown, underRepair, critical, major, minor, warning, indeterminate) and the possible values of standby states (entStateStandby: unknown, hotStandby, coldStandby, providingService).

From a power monitoring point of view, in contrast to the entity operational states of entities, Power States are required, as proposed in the Power and Energy Monitoring MIB module. Those Power States can be mapped to the different operational states in the ENTITY-STATE MIB, if a formal mapping is required. For example, the entStateStandby "unknown", "hotStandby", "coldStandby", states could map to the Power State "unknown", "ready", "standby", respectively, while the entStateStandby "providingService" could map to any "low" to "high" Power State.

7.3. Link with the POWER-OVER-ETHERNET MIB

Power-over-Ethernet MIB [RFC3621] provides an energy monitoring and configuration framework for power over Ethernet devices. The RFC introduces a concept of a port group on a switch to define power monitoring and management policy and does not use the entPhysicalIndex as the index. Indeed, the pethMainPseConsumptionPower is indexed by the pethMainPseGroupIndex, which has no mapping with the entPhysicalIndex.

One cannot assume that the Power-over-Ethernet MIB is implemented for all Energy Objects that need to be monitored. A typical example is a converged building gateway, monitoring several other devices in the building, doing the proxy between SNMP and a protocol like BACNET. Another example is the home energy controller. In such cases, the `eoethPortIndex` and `eoethPortGrpIndex` values contain the zero value, thanks to new `PethPsePortIndexOrZero` and textual `PethPsePortGroupIndexOrZero` conventions.

However, if the Power-over-Ethernet MIB [RFC3621] is supported, the Energy Object `eoethPortIndex` and `eoethPortGrpIndex` contain the `pethPsePortIndex` and `pethPsePortGroupIndex`, respectively.

As a consequence, the `entPhysicalIndex` MIB object has been kept as the unique Energy Object index.

Note that, even though the Power-over-Ethernet MIB [RFC3621] was created after the ENTITY-SENSOR MIB [RFC3433], it does not reuse the precision notion from the ENTITY-SENSOR MIB, i.e. the `entPhySensorPrecision` MIB object.

7.4. Link with the UPS MIB

To protect against unexpected power disruption, data centers and buildings make use of Uninterruptible Power Supplies (UPS). To protect critical assets, a UPS can be restricted to a particular subset or domain of the network. UPS usage typically lasts only for a finite period of time, until normal power supply is restored. Planning is required to decide on the capacity of the UPS based on output power and duration of probable power outage. To properly provision UPS power in a data center or building, it is important to first understand the total demand required to support all the entities in the site. This demand can be assessed and monitored via the Power and Energy Monitoring MIB.

UPS MIB [RFC1628] provides information on the state of the UPS network. Implementation of the UPS MIB is useful at the aggregate level of a data center or a building. The MIB module contains several groups of variables:

- `upsIdent`: Identifies the UPS entity (name, model, etc.).
- `upsBattery` group: Indicates the battery state (`upsbatteryStatus`, `upsEstimatedMinutesRemaining`, etc.)

Internet-Draft <Power and Energy Monitoring MIB> October 2012

- upsInput group: Characterizes the input load to the UPS (number of input lines, voltage, current, etc.).
- upsOutput: Characterizes the output from the UPS (number of output lines, voltage, current, etc.)
- upsAlarms: Indicates the various alarm events.

The measurement of power in the UPS MIB is in Volts, Amperes and Watts. The units of power measurement are RMS volts and RMS Amperes. They are not based on the EntitySensorDataScale and EntitySensorDataPrecision of ENTITY-SENSOR-MIB.

Both the Power and Energy Monitoring MIB and the UPS MIB may be implemented on the same UPS SNMP agent, without conflict. In this case, the UPS device itself is the Energy Object Parent and any of the UPS meters or submeters are the Energy Object Children.

7.5. Link with the LLDP and LLDP-MED MIBs

The LLDP Protocol is a Data Link Layer protocol used by network devices to advertise their identities, capabilities, and interconnections on a LAN network.

The Media Endpoint Discovery is an enhancement of LLDP, known as LLDP-MED. The LLDP-MED enhancements specifically address voice applications. LLDP-MED covers 6 basic areas: capability discovery, LAN speed and duplex discovery, network policy discovery, location identification discovery, inventory discovery, and power discovery.

Of particular interest to the current MIB module is the power discovery, which allows the endpoint device (such as a PoE phone) to convey power requirements to the switch. In power discovery, LLDP-MED has four Type Length Values (TLVs): power type, power source, power priority and power value. Respectively, those TLVs provide information related to the type of power (power sourcing entity versus powered device), how the device is powered (from the line, from a backup source, from external power source, etc.), the power priority (how important is it that this device has power?), and how much power the device needs.

The power priority specified in the LLDP-MED MIB [LLDP-MED-MIB] actually comes from the Power-over-Ethernet MIB [RFC3621]. If the Power-over-Ethernet MIB [RFC3621] is supported, the exact

Internet-Draft <Power and Energy Monitoring MIB> October 2012
value from the pethPsePortPowerPriority [RFC3621] is copied over
in the lldpXMedRemXPoEPDPowerPriority [LLDP-MED-MIB]; otherwise
the value in lldpXMedRemXPoEPDPowerPriority is "unknown". From
the Power and Energy Monitoring MIB, it is possible to identify
the pethPsePortPowerPriority [RFC3621], thanks to the
eoethPortIndex and eoethPortGrpIndex.

The lldpXMedLocXPoEPDPowerSource [LLDP-MED-MIB] is similar to
eoPowerOrigin in indicating if the power for an attached device
is local or from a remote device. If the LLDP-MED MIB is
supported, the following mapping can be applied to the
eoPowerOrigin: lldpXMedLocXPoEPDPowerSource fromPSE(2) and
local(3) can be mapped to remote(2) and self(1), respectively.

8. Implementation Scenario

This section provides an illustrative example scenario for the
implementation of the Energy Object, including Energy Object
Parent and Energy Object Child relationships.

Example Scenario of a campus network: Switch with PoE Endpoints
with further connected devices.

The campus network consists of switches that provide LAN
connectivity. The switch with PoE ports is located in wiring
closet. PoE IP phones are connected to the switch. The IP
phones draw power from the PoE ports of the switch. In
addition, a PC is daisy-chained from the IP phone for LAN
connectivity.


The IP phone consumes power from the PoE switch, while the PC
consumes power from the wall outlet.

The switch has implementations of ENTITY-MIB [EMAN-ENTITY] and
ENERGY-AWARE MIB [EMAN-AWARE-MIB] while the PC does not have
implementation of the ENTITY-MIB, but has an implementation of
ENERGY-AWARE MIB [EMAN-AWARE-MIB]. The switch has the following
attributes, entPhysicalIndex "1", and entPhysicalUUID "UUID
1000". The power usage of the switch is "440 Watts". The
switch does not have an Energy Object Parent.

The PoE switch port has the following attributes: The switch
port has entPhysicalIndex "3", and entPhysicalUUID is "UUID
1000:3". The power metered at the POE switch port is "12
watts". In this example, the POE switch port has the switch as
the Energy Object Parent, with its eoParentID of "1000".

The attributes of the PC are given below. The PC does not have an entPhysicalIndex, and the entPhysicalUUID is "UUID 1000:57 ". The PC has an Energy Object Parent, i.e. the switch port whose entPhysicalUUID is "UUID 1000:3". The power usage of the PC is "120 Watts" and is communicated to the switch port.

This example illustrates the important distinction between the Energy Object Children: The IP phone draws power from the switch, while the PC has LAN connectivity from the phone, but is powered from the wall outlet. However, the Energy Object Parent sends power control messages to both the Energy Object Children (IP phone and PC) and the Children react to those messages.



PC connected to switch via IP phone

PC entPhyIndx	PC UUID	PC eoParentID	PC eoPower
7	UUID 1000:57	UUID 1000:3	120

Figure 1: Example scenario

9. Structure of the MIB

The primary MIB object in this MIB module is the `energyObjectMibObject`. The `eoPowerTable` table of `energyObjectMibObject` describes the power measurement attributes of an Energy Object entity. The notion of identity of the device in terms of uniquely identification of the Energy Object and its relationship to other entities in the network are addressed in [EMAN-AWARE-MIB].

Logically, this MIB module is a sparse extension of the [EMAN-AWARE-MIB] module. Thus the following requirements which are applied to [EMAN-AWARE-MIB] are also applicable. As a requirement for this MIB module, [EMAN-AWARE-MIB] should be implemented and as Module Compliance of ENTITY-MIB V4 [EMAN-ENTITY] with respect to `entity4CRCompliance` should be supported which requires 3 MIB objects (`entPhysicalIndex`, `entPhysicalName` and `entPhysicalUUID`) MUST be implemented.

`eoMeterCapabilitiesTable` is useful to enable applications to determine the capabilities supported by the local management agent. This table indicates the energy monitoring MIB groups that are supported by the local management system. By reading the value of this object, it is possible for applications to know which tables contain the information and are usable without walking through the table and querying every element which involves a trial-and-error process.

The power measurement of an Energy Object contains information describing its power usage (`eoPower`) and its current power state (`eoPowerOperState`). In addition to power usage, additional

Internet-Draft <Power and Energy Monitoring MIB> October 2012
information describing the units of measurement
(eoPowerAccuracy, eoPowerUnitMultiplier), how power usage
measurement was obtained (eoPowerMeasurementCaliber), the
source of power (eoPowerOrigin) and the type of power
(eoPowerCurrentTtype) are described.

An Energy Object may contain an optional eoPowerCharacteristics
table that describes the electrical characteristics associated
with the current power state and usage.

An Energy Object may contain an optional eoEnergyTable to
describe energy measurement information over time.

An Energy Object may also contain optional battery information
associated with this entity.

10. MIB Definitions

```
-- *****  
--  
--  
-- This MIB is used to monitor power usage of network  
-- devices  
--  
-- *****
```

ENERGY-OBJECT-MIB DEFINITIONS ::= BEGIN

IMPORTS

```
    MODULE-IDENTITY,  
    OBJECT-TYPE,  
    NOTIFICATION-TYPE,  
    mib-2,  
    Integer32, Counter32, TimeTicks  
        FROM SNMPv2-SMI  
    TEXTUAL-CONVENTION, DisplayString, RowStatus, TimeInterval,  
    TimeStamp  
        FROM SNMPv2-TC  
    MODULE-COMPLIANCE, NOTIFICATION-GROUP, OBJECT-GROUP  
        FROM SNMPv2-CONF  
    OwnerString  
        FROM RMON-MIB  
    entPhysicalIndex, PhysicalIndex  
        FROM ENTITY-MIB;
```

Internet-Draft <Power and Energy Monitoring MIB> October 2012
energyObjectMib MODULE-IDENTITY
LAST-UPDATED "201210220000Z" -- 22 October 2012

ORGANIZATION "IETF EMAN Working Group"
CONTACT-INFO

"WG charter:
<http://datatracker.ietf.org/wg/eman/charter/>

Mailing Lists:

General Discussion: eman@ietf.org

To Subscribe:

<https://www.ietf.org/mailman/listinfo/eman>

Archive:

<http://www.ietf.org/mail-archive/web/eman>

Editors:

Mouli Chandramouli
Cisco Systems, Inc.
Sarjapur Outer Ring Road
Bangalore 560103
IN
Phone: +91 80 4429 2409
Email: moulchan@cisco.com

Brad Schoening
44 Rivers Edge Drive
Little Silver, NJ 07739
US
Email: brad.schoening@verizon.net

Juergen Quittek
NEC Europe Ltd.
NEC Laboratories Europe
Network Research Division
Kurfuersten-Anlage 36
Heidelberg 69115
DE
Phone: +49 6221 4342-115
Email: quittek@neclab.eu

Thomas Dietz
NEC Europe Ltd.
NEC Laboratories Europe
Network Research Division

Internet-Draft <Power and Energy Monitoring MIB> October 2012
Kurfuersten-Anlage 36
69115 Heidelberg
DE
Phone: +49 6221 4342-128
Email: Thomas.Dietz@nw.neclab.eu

Benoit Claise
Cisco Systems, Inc.
De Kleetlaan 6a b1
Degem 1831
Belgium
Phone: +32 2 704 5622
Email: bclaise@cisco.com"

DESCRIPTION

"This MIB is used to monitor power and energy in devices.

This table sparse extension of the eoTable from the ENERGY-AWARE-MIB. As a requirement [EMAN-AWARE-MIB] should be implemented.

Module Compliance of ENTITY-MIB v4 with respect to entity4CRCompliance should be supported which requires implementation of 3 MIB objects (entPhysicalIndex, entPhysicalName and entPhysicalUUID)."

REVISION

"201210220000Z" -- 22 October 2012

DESCRIPTION

"Initial version, published as RFC XXXX."

::= { mib-2 xxx }

energyObjectMibNotifs OBJECT IDENTIFIER
::= { energyObjectMib 0 }

energyObjectMibObjects OBJECT IDENTIFIER
::= { energyObjectMib 1 }

energyObjectMibConform OBJECT IDENTIFIER
::= { energyObjectMib 2 }

IANAPowerStateSet ::= TEXTUAL-CONVENTION
 STATUS current
 DESCRIPTION

"IANAPowerState is a textual convention that describes Power State Sets and Power State Set Values an Energy Object supports. IANA has created a registry of Power State supported by an Energy Object and IANA shall administer the list of Power State Sets and Power States.

The textual convention assumes that power states in a power state set are limited to 255 distinct values. For a Power State Set S, the named number with the value S * 256 is allocated to indicate the power state set. For a Power State X in the Power State S, the named number with the value S * 256 + X + 1 is allocated to represent the power state."

REFERENCE

"<http://www.iana.org/assignments/eman>
RFC EDITOR NOTE: please change the previous URL if this is not the correct one after IANA assigned it."

SYNTAX INTEGER {
 other(0), -- indicates other set
 unknown(255), -- unknown power state

 ieee1621(256), -- indicates IEEE1621 set
 ieee1621On(257),
 ieee1621Off(258),
 ieee1621Sleep(259),

 dmtf(512), -- indicates DMTF set
 dmtfOn(513),
 dmtfSleepLight(514),
 dmtfSleepDeep(515),
 dmtfOffHard(516),
 dmtfOffSoft(517),
 dmtfHibernate(518),
 dmtfPowerOffSoft(519),
 dmtfPowerOffHard(520),
 dmtfMasterBusReset(521),
 dmtfDiagnosticInterrupt(522),
 dmtfOffSoftGraceful(523),

```
dmtfOffHardGraceful(524),
dmtfMasterBusResetGraceful(525),
dmtfPowerCycleOffSoftGraceful(526),
dmtfPowerCycleHardGraceful(527),

eman(1024),          -- indicates EMAN set
emanmechoff(1025),
emansoftoff(1026),
emanhibernate(1027),
emansleep(1028),
emanstandby(1029),
emanready(1030),
emanlowMinus(1031),
emanlow(1032),
emanmediumMinus(1033),
emanmedium(1034),
emanhighMinus(1035),
emanhigh(1036)
}
```

UnitMultiplier ::= TEXTUAL-CONVENTION

STATUS current

DESCRIPTION

"The Unit Multiplier is an integer value that represents the IEEE 61850 Annex A units multiplier associated with the integer units used to measure the power or energy.

For example, when used with eoPowerUnitMultiplier, -3 represents 10⁻³ or milliwatts."

REFERENCE

"The International System of Units (SI),
National Institute of Standards and Technology,
Spec. Publ. 330, August 1991."

SYNTAX INTEGER {

```
yocto(-24),  -- 10^-24
zepto(-21),  -- 10^-21
atto(-18),   -- 10^-18
femto(-15),  -- 10^-15
pico(-12),   -- 10^-12
nano(-9),    -- 10^-9
micro(-6),   -- 10^-6
milli(-3),   -- 10^-3
units(0),    -- 10^0
kilo(3),     -- 10^3
mega(6),     -- 10^6
giga(9),     -- 10^9
tera(12),    -- 10^12
peta(15),    -- 10^15
```

```
        exa(18),      -- 10^18
        zetta(21),   -- 10^21
        yotta(24)    -- 10^24
    }

-- Objects

eoMeterCapabilitiesTable OBJECT-TYPE
    SYNTAX      SEQUENCE OF EoMeterCapabilitiesEntry
    MAX-ACCESS   not-accessible
    STATUS      current
    DESCRIPTION
        "This table is useful for helping applications determine the
        monitoring capabilities supported by the local management
        agents. It is possible for applications to know which tables
        are usable without going through a trial-and-error process."
        ::= { energyObjectMibObjects 1 }

eoMeterCapabilitiesEntry OBJECT-TYPE
    SYNTAX      EoMeterCapabilitiesEntry
    MAX-ACCESS   not-accessible
    STATUS      current
    DESCRIPTION
        "An entry describes the metering capability of an Energy
        Object."
    INDEX       { entPhysicalIndex }
    ::= { eoMeterCapabilitiesTable 1 }

EoMeterCapabilitiesEntry ::= SEQUENCE {
    eoMeterCapability          BITS
}

eoMeterCapability OBJECT-TYPE
    SYNTAX      BITS {
        none(0),
        powermetering(1),      -- power measurement
        energymetering(2),     -- energy measurement
        powercharacteristics(3) -- power characteristics
    }
    MAX-ACCESS   read-only
    STATUS      current
    DESCRIPTION
        "An indication of the Energy monitoring capabilities supported
        by this agent. This object use a BITS syntax and indicate the
```


Internet-Draft <Power and Energy Monitoring MIB> October 2012
 MIB groups supported by the probe. By reading the value of this
 object, it is possible to determine the MIB tables supported. "
 ::= { eoMeterCapabilitiesEntry 1 }

eoPowerTable OBJECT-TYPE
 SYNTAX SEQUENCE OF EoPowerEntry
 MAX-ACCESS not-accessible
 STATUS current
 DESCRIPTION
 "This table lists Energy Objects."
 ::= { energyObjectMibObjects 2 }

eoPowerEntry OBJECT-TYPE
 SYNTAX EoPowerEntry
 MAX-ACCESS not-accessible
 STATUS current
 DESCRIPTION
 "An entry describes the power usage of an Energy Object."
 INDEX { entPhysicalIndex }
 ::= { eoPowerTable 1 }

EoPowerEntry ::= SEQUENCE {
 eoPower Integer32,
 eoPowerNameplate Integer32,
 eoPowerUnitMultiplier UnitMultiplier,
 eoPowerAccuracy Integer32,
 eoPowerMeasurementCaliber INTEGER,
 eoPowerCurrentType INTEGER,
 eoPowerOrigin INTEGER,
 eoPowerAdminState IANAPowerStateSet,
 eoPowerOperState IANAPowerStateSet,
 eoPowerStateEnterReason OwnerString
 }

eoPower OBJECT-TYPE
 SYNTAX Integer32
 UNITS "Watts"
 MAX-ACCESS read-only
 STATUS current
 DESCRIPTION

"This object indicates the power measured for the Energy Object. For alternating current, this value is obtained as an average over fixed number of AC cycles. . This value is specified in SI units of watts with the magnitude of watts (milliwatts, kilowatts, etc.) indicated separately in eoPowerUnitMultiplier. The accuracy of the measurement is specified in eoPowerAccuracy. The direction of power flow is indicated by the sign on eoPower. If the Energy Object is consuming power, the eoPower value will be positive. If the Energy Object is producing power, the eoPower value will be negative.

The eoPower MUST be less than or equal to the maximum power that can be consumed at the power state specified by eoPowerState.

The eoPowerMeasurementCaliber object specifies how the usage value reported by eoPower was obtained. The eoPower value must report 0 if the eoPowerMeasurementCaliber is 'unavailable'. For devices that can not measure or report power, this option can be used."

::= { eoPowerEntry 1 }

eoPowerNameplate OBJECT-TYPE

SYNTAX Integer32

UNITS "Watts"

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"This object indicates the rated maximum consumption for the fully populated Energy Object. The nameplate power requirements are the maximum power numbers and, in almost all cases, are well above the expected operational consumption. The eoPowerNameplate is widely used for power provisioning. This value is specified in either units of watts or voltage and current. The units are therefore SI watts or equivalent Volt-Amperes with the magnitude (milliwatts, kilowatts, etc.) indicated separately in eoPowerUnitMultiplier."

::= { eoPowerEntry 2 }

eoPowerUnitMultiplier OBJECT-TYPE

SYNTAX UnitMultiplier

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"The magnitude of watts for the usage value in eoPower
and eoPowerNameplate."

::= { eoPowerEntry 3 }

eoPowerAccuracy OBJECT-TYPE

SYNTAX Integer32 (0..10000)

UNITS "hundredths of percent"

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"This object indicates a percentage value, in 100ths of a percent, representing the assumed accuracy of the usage reported by eoPower. For example: The value 1010 means the reported usage is accurate to +/- 10.1 percent. This value is zero if the accuracy is unknown or not applicable based upon the measurement method."

ANSI and IEC define the following accuracy classes for power measurement:

IEC 62053-22 60044-1 class 0.1, 0.2, 0.5, 1 3.

ANSI C12.20 class 0.2, 0.5"

::= { eoPowerEntry 4 }

eoPowerMeasurementCaliber OBJECT-TYPE

SYNTAX INTEGER {
unavailable(1) ,
unknown(2),
actual(3) ,
estimated(4),
presumed(5)
}

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"This object specifies how the usage value reported by eoPower was obtained:

- unavailable(1): Indicates that the usage is not available. In such a case, the eoPower value must be 0 for devices that can not measure or report power this option can be used.

- unknown(2): Indicates that the way the usage was determined is unknown. In some cases, entities report aggregate power on behalf of another device. In such cases it is not known whether the usage reported is actual(2), estimated(3) or presumed (4).

Internet-Draft <Power and Energy Monitoring MIB> October 2012
- actual(3): Indicates that the reported usage was measured by the entity through some hardware or direct physical means. The usage data reported is not presumed (4) or estimated (3) but the real apparent current energy consumption rate.

- estimated(4): Indicates that the usage was not determined by physical measurement. The value is a derivation based upon the device type, state, and/or current utilization using some algorithm or heuristic. It is presumed that the entity's state and current configuration were used to compute the value.

- presumed(5): Indicates that the usage was not determined by physical measurement, algorithm or derivation. The usage was reported based upon external tables, specifications, and/or model information. For example, a PC Model X draws 200W, while a PC Model Y draws 210W"

::= { eoPowerEntry 5 }

eoPowerCurrentType OBJECT-TYPE
SYNTAX INTEGER {
ac(1),
dc(2),
unknown(3)
}
MAX-ACCESS read-only
STATUS current
DESCRIPTION
"This object indicates whether the eoUsage for the Energy Object reports alternative current AC(1), direct current DC(2), or that the current type is unknown(3)."
::= { eoPowerEntry 6 }

eoPowerOrigin OBJECT-TYPE
SYNTAX INTEGER {
self (1),
remote (2)
}
MAX-ACCESS read-only
STATUS current
DESCRIPTION
"This object indicates the source of power measurement and can be useful when modeling the power usage of attached devices. The power measurement can be performed by the entity itself or the power measurement of the

Internet-Draft <Power and Energy Monitoring MIB> October 2012
entity can be reported by another trusted entity using a
protocol extension. A value of self(1) indicates the
measurement is performed by the entity, whereas remote(2)
indicates that the measurement was performed by another
entity."

::= { eoPowerEntry 7 }

eoPowerAdminState OBJECT-TYPE

SYNTAX IANAPowerStateSet

MAX-ACCESS read-write

STATUS current

DESCRIPTION

"This object specifies the desired Power State and the
Power State Set for the Energy Object. Note that
other(0) is not a Power State Set and unknown(255) is
not a Power State as such, but simply an indication that
the Power State of the Energy Object is unknown.

Possible values of eoPowerAdminState within the Power
State Set are registered at IANA.

A current list of assignments can be found at

<<http://www.iana.org/assignments/eman>>

RFC-EDITOR: please check the location after IANA"

::= { eoPowerEntry 8 }

eoPowerOperState OBJECT-TYPE

SYNTAX IANAPowerStateSet

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"This object specifies the current operational Power
State and the Power State Set for the Energy Object.
other(0) is not a Power State Set and unknown(255) is
not a Power State as such, but simply an indication that
the Power State of the Energy Object is unknown.

Possible values of eoPowerAdminState within the Power
State Set are registered at IANA.

A current list of assignments can be found at

<<http://www.iana.org/assignments/eman>>

RFC-EDITOR: please check the location after IANA"

::= { eoPowerEntry 9 }

eoPowerStateEnterReason OBJECT-TYPE

SYNTAX OwnerString

MAX-ACCESS read-create

STATUS current

DESCRIPTION

"This string object describes the reason for the eoPowerAdminState transition. Alternatively, this string may contain with the entity that configured this Energy Object to this Power State."

DEFVAL { "" }

::= { eoPowerEntry 10 }

eoPowerStateTable OBJECT-TYPE

SYNTAX SEQUENCE OF EoPowerStateEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"This table enumerates the maximum power usage, in watts, for every single supported Power State of each Energy Object."

This table has an expansion-dependent relationship on the eoPowerTable, containing rows describing each Power State for the corresponding Energy Object. For every Energy Object in the eoPowerTable, there is a corresponding entry in this table."

::= { energyObjectMibObjects 3 }

eoPowerStateEntry OBJECT-TYPE

SYNTAX EoPowerStateEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"A eoPowerStateEntry extends a corresponding eoPowerEntry. This entry displays max usage values at every single possible Power State supported by the Energy Object."

For example, given the values of a Energy Object corresponding to a maximum usage of 11W at the state 1 (mechoff), 6 (ready), 8 (mediumMinus), 12 (High):

State	MaxUsage	Units
1 (mechoff)	0	W
2 (softoff)	0	W
3 (hibernate)	0	W
4 (sleep)	0	W
5 (standby)	0	W
6 (ready)	8	W
7 (lowMinus)	8	W
8 (low)	11	W

9 (medimMinus)	11	W
10 (medium)	11	W
11 (highMinus)	11	W
12 (high)	11	W

Furthermore, this table extends to return the total time in each Power State, along with the number of times a particular Power State was entered."

```

INDEX      { entPhysicalIndex,
              eoPowerStateIndex
            }
 ::= { eoPowerStateTable 1 }

EoPowerStateEntry ::= SEQUENCE {
    eoPowerStateIndex          IANAPowerStateSet,
    eoPowerStateMaxPower      Integer32,
    eoPowerStatePowerUnitMultiplier  UnitMultiplier,
    eoPowerStateTotalTime     TimeTicks,
    eoPowerStateEnterCount    Counter32
}

eoPowerStateIndex OBJECT-TYPE
    SYNTAX          IANAPowerStateSet
    MAX-ACCESS      not-accessible
    STATUS          current
    DESCRIPTION
        "
        This object specifies the index of the Power State of
        the Energy Object within a Power State Set. The
        semantics of the specific Power State can be obtained
        from the Power State Set definition."
    ::= { eoPowerStateEntry 1 }

eoPowerStateMaxPower OBJECT-TYPE
    SYNTAX          Integer32
    UNITS           "Watts"
    MAX-ACCESS      read-only
    STATUS          current
    DESCRIPTION
        "This object indicates the maximum power for the Energy
        Object at the particular Power State. This value is
        specified in SI units of watts with the magnitude of the
        units (milliwatts, kilowatts, etc.) indicated separately
        in eoPowerStatePowerUnitMultiplier. If the maximum power
        is not known for a certain Power State, then the value is
        encoded as 0xFFFF."

```

Internet-Draft <Power and Energy Monitoring MIB> October 2012
For Power States not enumerated, the value of
eoPowerStateMaxPower might be interpolated by using the
next highest supported Power State."

::= { eoPowerStateEntry 2 }

eoPowerStatePowerUnitMultiplier OBJECT-TYPE

SYNTAX UnitMultiplier

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"The magnitude of watts for the usage value in
eoPowerStateMaxPower."

::= { eoPowerStateEntry 3 }

eoPowerStateTotalTime OBJECT-TYPE

SYNTAX TimeTicks

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"This object indicates the total time in hundreds
of seconds that the Energy Object has been in this power
state since the last reset, as specified in the
sysUpTime."

::= { eoPowerStateEntry 4 }

eoPowerStateEnterCount OBJECT-TYPE

SYNTAX Counter32

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"This object indicates how often the Energy
Object has
entered this power state, since the last reset of the
device as specified in the sysUpTime."

::= { eoPowerStateEntry 5 }

eoEnergyParametersTable OBJECT-TYPE

SYNTAX SEQUENCE OF EoEnergyParametersEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"This table is used to configure the parameters for
Energy measurement collection in the table
eoEnergyTable. This table allows the configuration of
different measurement settings on the same Energy


```
Object."
 ::= { energyObjectMibObjects 4 }

eoEnergyParametersEntry OBJECT-TYPE
    SYNTAX      EoEnergyParametersEntry
    MAX-ACCESS   not-accessible
    STATUS      current
    DESCRIPTION
        "An entry controls an energy measurement in
        eoEnergyTable."
    INDEX { eoEnergyParametersIndex }
    ::= { eoEnergyParametersTable 1 }

EoEnergyParametersEntry ::= SEQUENCE {
    eoEnergyObjectIndex      PhysicalIndex,
    eoEnergyParametersIndex  Integer32,
    eoEnergyParametersIntervalLength  TimeInterval,
    eoEnergyParametersIntervalNumber  Integer32,
    eoEnergyParametersIntervalMode    Integer32,
    eoEnergyParametersIntervalWindow  TimeInterval,
    eoEnergyParametersSampleRate      Integer32,
    eoEnergyParametersStatus          RowStatus
}

eoEnergyObjectIndex OBJECT-TYPE
    SYNTAX      PhysicalIndex
    MAX-ACCESS   read-create
    STATUS      current
    DESCRIPTION
        "The unique value, to identify the specific Energy Object
        on which the measurement is applied, the same index used
        in the eoPowerTable to identify the Energy Object."
    ::= { eoEnergyParametersEntry 1 }

eoEnergyParametersIndex OBJECT-TYPE
    SYNTAX      Integer32 (0..2147483647)
    MAX-ACCESS   read-create
    STATUS      current
    DESCRIPTION
        "This object specifies the index of the Energy
        Parameters setting for collection of energy measurements
        for an Energy Object. An Energy Object can have multiple
        eoEnergyParametersIndex, depending on the capability of
        the Energy Object"
    ::= { eoEnergyParametersEntry 2 }

eoEnergyParametersIntervalLength OBJECT-TYPE
```

SYNTAX TimeInterval
MAX-ACCESS read-create
STATUS current

DESCRIPTION

"This object indicates the length of time in hundredth of seconds over which to compute the average eoEnergyConsumed measurement in the eoEnergyTable table. The computation is based on the Energy Object's internal sampling rate of power consumed or produced by the Energy Object. The sampling rate is the rate at which the Energy Object can read the power usage and may differ based on device capabilities. The average energy consumption is then computed over the length of the interval."

DEFVAL { 90000 }
::= { eoEnergyParametersEntry 3 }

eoEnergyParametersIntervalNumber OBJECT-TYPE

SYNTAX Integer32
MAX-ACCESS read-create
STATUS current

DESCRIPTION

"The number of intervals maintained in the eoEnergyTable. Each interval is characterized by a specific eoEnergyCollectionStartTime, used as an index to the table eoEnergyTable. Whenever the maximum number of entries is reached, the measurement over the new interval replacesthe oldest measurement. There is one exception to this rule: when the eoEnergyMaxConsumed and/or eoEnergyMaxProduced are in (one of) the two oldest measurement(s), they are left untouched and the next oldest measurement is replaced."

DEFVAL { 10 }
::= { eoEnergyParametersEntry 4 }

eoEnergyParametersIntervalMode OBJECT-TYPE

SYNTAX INTEGER {
 period(1),
 sliding(2),
 total(3)
 }

MAX-ACCESS read-create
STATUS current

DESCRIPTION

"A control object to define the mode of interval calculation for the computation of the average eoEnergyConsumed or eoEnergyProduced measurement in the eoEnergyTable table."

Internet-Draft <Power and Energy Monitoring MIB> October 2012
A mode of period(1) specifies non-overlapping periodic measurements.

A mode of sliding(2) specifies overlapping sliding windows where the interval between the start of one interval and the next is defined in eoEnergyParametersIntervalWindow.

A mode of total(3) specifies non-periodic measurement. In this mode only one interval is used as this is a continuous measurement since the last reset. The value of eoEnergyParametersIntervalNumber should be (1) one and eoEnergyParametersIntervalLength is ignored. "

::= { eoEnergyParametersEntry 5 }

eoEnergyParametersIntervalWindow OBJECT-TYPE

SYNTAX TimeInterval

MAX-ACCESS read-create

STATUS current

DESCRIPTION

"The length of the duration window between the starting time of one sliding window and the next starting time in hundredth of seconds, in order to compute the average of eoEnergyConsumed, eoEnergyProduced measurements in the eoEnergyTable table. This is valid only when the eoEnergyParametersIntervalMode is sliding(2). The eoEnergyParametersIntervalWindow value should be a multiple of eoEnergyParametersSampleRate."

::= { eoEnergyParametersEntry 6 }

eoEnergyParametersSampleRate OBJECT-TYPE

SYNTAX Integer32

UNITS "Milliseconds"

MAX-ACCESS read-create

STATUS current

DESCRIPTION

"The sampling rate, in milliseconds, at which the Energy Object should poll power usage in order to compute the average eoEnergyConsumed, eoEnergyProduced measurements in the table eoEnergyTable. The Energy Object should initially set this sampling rate to a reasonable value, i.e., a compromise between intervals that will provide good accuracy by not being too long, but not so short that they affect the Energy Object performance by requesting continuous polling. If the sampling rate is unknown, the value 0 is reported. The sampling rate should be selected so that eoEnergyParametersIntervalWindow is a multiple of eoEnergyParametersSampleRate."

DEFVAL { 1000 }

::= { eoEnergyParametersEntry 7 }

eoEnergyParametersStatus OBJECT-TYPE

SYNTAX RowStatus

MAX-ACCESS read-create

STATUS current

DESCRIPTION

"The status of this row. The eoEnergyParametersStatus is used to start or stop energy usage logging. An entry status may not be active(1) unless all objects in the entry have an appropriate value. If this object is not equal to active(1), all associated usage-data logged into the eoEnergyTable will be deleted. The data can be destroyed by setting up the eoEnergyParametersStatus to destroy(2)."

::= { eoEnergyParametersEntry 8 }

eoEnergyTable OBJECT-TYPE

SYNTAX SEQUENCE OF EoEnergyEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"This table lists Energy Object energy measurements. Entries in this table are only created if the corresponding value of object eoPowerMeasurementCaliber is active(2), i.e., if the power is actually metered."

::= { energyObjectMibObjects 5 }

eoEnergyEntry OBJECT-TYPE

SYNTAX EoEnergyEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"An entry describing energy measurements."

INDEX { eoEnergyParametersIndex,

eoEnergyCollectionStartTime }

::= { eoEnergyTable 1 }

EoEnergyEntry ::= SEQUENCE {

eoEnergyCollectionStartTime TimeTicks,

eoEnergyConsumed Integer32,

eoEnergyProduced Integer32,

eoEnergyNet Integer32,

eoEnergyUnitMultiplier UnitMultiplier,

eoEnergyAccuracy Integer32,

```
    eoEnergyMaxConsumed      Integer32,
    eoEnergyMaxProduced      Integer32,
    eoEnergyDiscontinuityTime TimeStamp
}
```

eoEnergyCollectionStartTime OBJECT-TYPE

```
SYNTAX      TimeTicks
UNITS       "hundredths of seconds"
MAX-ACCESS  not-accessible
STATUS      current
DESCRIPTION
    "The time (in hundredths of a second) since the
    network management portion of the system was last
    re-initialized, as specified in the sysUpTime [RFC3418].
    This object is useful for reference of interval periods
    for which the energy is measured."
 ::= { eoEnergyEntry 1 }
```

eoEnergyConsumed OBJECT-TYPE

```
SYNTAX      Integer32
UNITS       "Watt-hours"
MAX-ACCESS  read-only
STATUS      current
DESCRIPTION
    "This object indicates the energy consumed in units of watt-
    hours for the Energy Object over the defined interval.
    This value is specified in the common billing units of watt-
    hours with the magnitude of watt-hours (kW-Hr, MW-Hr, etc.)
    indicated separately in eoEnergyUnitMultiplier."
 ::= { eoEnergyEntry 2 }
```

eoEnergyProduced OBJECT-TYPE

```
SYNTAX      Integer32
UNITS       "Watt-hours"
MAX-ACCESS  read-only
STATUS      current
DESCRIPTION
    "This object indicates the energy produced in units of watt-
    hours for the Energy Object over the defined interval.
    This value is specified in the common billing units of watt-
    hours with the magnitude of watt-hours (kW-Hr, MW-Hr, etc.)
    indicated separately in eoEnergyUnitMultiplier."
 ::= { eoEnergyEntry 3 }
```

eoEnergyNet OBJECT-TYPE

```
SYNTAX      Integer32
UNITS       "Watt-hours"
```

MAX-ACCESS read-only
STATUS current
DESCRIPTION

"This object indicates the resultant of the energy consumed and energy produced for an energy object in units of watt-hours for the Energy Object over the defined interval. This value is specified in the common billing units of watt-hours with the magnitude of watt-hours (kW-Hr, MW-Hr, etc.) indicated separately in eoEnergyUnitMultiplier."
 ::= { eoEnergyEntry 4 }

eoEnergyUnitMultiplier OBJECT-TYPE

SYNTAX UnitMultiplier
MAX-ACCESS read-only
STATUS current
DESCRIPTION

"This object is the magnitude of watt-hours for the energy field in eoEnergyConsumed, eoEnergyProduced, eoEnergyNet, eoEnergyMaxConsumed, and eoEnergyMaxProduced."
 ::= { eoEnergyEntry 5 }

eoEnergyAccuracy OBJECT-TYPE

SYNTAX Integer32 (0..10000)
UNITS "hundredths of percent"
MAX-ACCESS read-only
STATUS current
DESCRIPTION

"This object indicates a percentage value, in 100ths of a percent, representing the presumed accuracy of Energy usage reporting. eoEnergyAccuracy is applicable to all Energy measurements in the eoEnergyTable.

For example: 1010 means the reported usage is accurate to +/- 10.1 percent.
This value is zero if the accuracy is unknown."

::= { eoEnergyEntry 6 }

eoEnergyMaxConsumed OBJECT-TYPE

SYNTAX Integer32
UNITS "Watt-hours"
MAX-ACCESS read-only
STATUS current
DESCRIPTION

Internet-Draft <Power and Energy Monitoring MIB> October 2012

"This object is the maximum energy ever observed in eoEnergyConsumed since the monitoring started. This value is specified in the common billing units of watt-hours with the magnitude of watt-hours (kW-Hr, MW-Hr, etc.) indicated separately in eoEnergyUnitMultiplier."

::= { eoEnergyEntry 7 }

eoEnergyMaxProduced OBJECT-TYPE

SYNTAX Integer32

UNITS "Watt-hours"

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"This object is the maximum energy ever observed in eoEnergyEnergyProduced since the monitoring started. This value is specified in the units of watt-hours with the magnitude of watt-hours (kW-Hr, MW-Hr, etc.) indicated separately in eoEnergyEnergyUnitMultiplier."

::= { eoEnergyEntry 8 }

eoEnergyDiscontinuityTime OBJECT-TYPE

SYNTAX TimeStamp

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"The value of sysUpTime [RFC3418] on the most recent occasion at which any one or more of this entity's energy counters in this table suffered a discontinuity: eoEnergyConsumed, eoEnergyProduced or eoEnergyNet. If no such discontinuities have occurred since the last re-initialization of the local management subsystem, then this object contains a zero value."

::= { eoEnergyEntry 9 }

-- Notifications

eoPowerStateChange NOTIFICATION-TYPE

OBJECTS {eoPowerAdminState, eoPowerOperState, eoPowerStateEnterReason}

STATUS current

DESCRIPTION

"The SNMP entity generates the eoPowerStateChange when the value(s) of eoPowerAdminState or eoPowerOperState, in the context of the Power State Set, have changed for the Energy Object represented by the entPhysicalIndex."

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 ::= { energyObjectMibNotifs 1 }

-- Conformance

energyObjectMibCompliances OBJECT IDENTIFIER
 ::= { energyObjectMib 3 }

energyObjectMibGroups OBJECT IDENTIFIER
 ::= { energyObjectMib 4 }

energyObjectMibFullCompliance MODULE-COMPLIANCE

STATUS current

DESCRIPTION

"When this MIB is implemented with support for read-create, then such an implementation can claim full compliance. Such devices can then be both monitored and configured with this MIB.

Module Compliance of [EMAN-ENTITY]
with respect to entity4CRCompliance should be supported which requires implementation of 3 MIB objects (entPhysicalIndex, entPhysicalName and entPhysicalUUID)."

MODULE -- this module

MANDATORY-GROUPS {
 energyObjectMibTableGroup,
 energyObjectMibStateTableGroup,
 energyObjectMibNotifGroup
 }

GROUP energyObjectMibEnergyTableGroup

DESCRIPTION "A compliant implementation does not have to implement.

Module Compliance of [EMAN-ENTITY]
with respect to entity4CRCompliance should be supported which requires implementation of 3 MIB objects (entPhysicalIndex, entPhysicalName and entPhysicalUUID)."

GROUP energyObjectMibEnergyParametersTableGroup

DESCRIPTION "A compliant implementation does not have to implement.

Internet-Draft <Power and Energy Monitoring MIB> October 2012

Module Compliance of {EMAN-ENTITY}
with respect to entity4CRCompliance should
be supported which requires implementation
of 3 MIB objects (entPhysicalIndex,
entPhysicalName and entPhysicalUUID)."

GROUP energyObjectMibMeterCapabilitiesTableGroup

DESCRIPTION "A compliant implementation does not
have to implement.

Module Compliance of [EMAN-ENTITY]
with respect to entity4CRCompliance should
be supported which requires implementation
of 3 MIB objects (entPhysicalIndex,
entPhysicalName and entPhysicalUUID)."

::= { energyObjectMibCompliances 1 }

energyObjectMibReadOnlyCompliance MODULE-COMPLIANCE

STATUS current

DESCRIPTION

"When this MIB is implemented without support for
read-create (i.e. in read-only mode), then such an
implementation can claim read-only compliance. Such a
device can then be monitored but cannot be
configured with this MIB.

Module Compliance of [EMAN-ENTITY]
with respect to entity4CRCompliance should
be supported which requires implementation
of 3 MIB objects (entPhysicalIndex,
entPhysicalName and entPhysicalUUID)."

MODULE -- this module

MANDATORY-GROUPS {
energyObjectMibTableGroup,
energyObjectMibStateTableGroup,
energyObjectMibNotifGroup
}

OBJECT eoPowerOperState

MIN-ACCESS read-only

DESCRIPTION

"Write access is not required."

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 ::= { energyObjectMibCompliances 2 }

-- Units of Conformance

energyObjectMibTableGroup OBJECT-GROUP
 OBJECTS {
 eoPower,
 eoPowerNameplate,
 eoPowerUnitMultiplier,
 eoPowerAccuracy,
 eoPowerMeasurementCaliber,
 eoPowerCurrentType,
 eoPowerOrigin,
 eoPowerAdminState,
 eoPowerOperState,
 eoPowerStateEnterReason
 }
 STATUS current
 DESCRIPTION
 "This group contains the collection of all the objects
 related to the Energy Object."
 ::= { energyObjectMibGroups 1 }

energyObjectMibStateTableGroup OBJECT-GROUP
 OBJECTS {
 eoPowerStateMaxPower,
 eoPowerStatePowerUnitMultiplier,
 eoPowerStateTotalTime,
 eoPowerStateEnterCount
 }
 STATUS current
 DESCRIPTION
 "This group contains the collection of all the
 objects related to the Power State."
 ::= { energyObjectMibGroups 2 }

energyObjectMibEnergyParametersTableGroup OBJECT-GROUP
 OBJECTS {
 eoEnergyObjectIndex,
 eoEnergyParametersIndex,
 eoEnergyParametersIntervalLength,
 eoEnergyParametersIntervalNumber,
 eoEnergyParametersIntervalMode,
 eoEnergyParametersIntervalWindow,
 eoEnergyParametersSampleRate,
 eoEnergyParametersStatus
 }

```
    }
    STATUS          current
    DESCRIPTION
        "This group contains the collection of all the objects
        related to the configuration of the Energy Table."
    ::= { energyObjectMibGroups 3 }
```

energyObjectMibEnergyTableGroup OBJECT-GROUP

```
    OBJECTS
    {
        -- Note that object
        -- eoEnergyCollectionStartTime is not
        -- included since it is not-accessible

        eoEnergyConsumed,
        eoEnergyProduced,
        eoEnergyNet,
        eoEnergyUnitMultiplier,
        eoEnergyAccuracy,
        eoEnergyMaxConsumed,
        eoEnergyMaxProduced,
        eoEnergyDiscontinuityTime
    }
    STATUS          current
    DESCRIPTION
        "This group contains the collection of all the objects
        related to the Energy Table."
    ::= { energyObjectMibGroups 4 }
```

energyObjectMibMeterCapabilitiesTableGroup OBJECT-GROUP

```
    OBJECTS
    {
        eoMeterCapability
    }
    STATUS          current
    DESCRIPTION
        "This group contains the object indicating the
        capability of the Energy Object"
    ::= { energyObjectMibGroups 5 }
```

energyObjectMibNotifGroup NOTIFICATION-GROUP

```
    NOTIFICATIONS
    {
        eoPowerStateChange
    }
    STATUS          current
    DESCRIPTION
        "This group contains the notifications for the power and
        energy monitoring MIB Module."
```

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 ::= { energyObjectMibGroups 6 }

END

```
-- *****
--
-- This MIB module is used to monitor power characteristics of
-- networked devices with measurements.
--
-- This MIB module is an extension of energyObjectMib module.
--
-- *****
```

POWER-CHARACTERISTICS-MIB DEFINITIONS ::= BEGIN

IMPORTS

 MODULE-IDENTITY,
 OBJECT-TYPE,
 mib-2,
 Integer32
 FROM SNMPv2-SMI
 MODULE-COMPLIANCE,
 OBJECT-GROUP
 FROM SNMPv2-CONF
 UnitMultiplier
 FROM ENERGY-OBJECT-MIB
 OwnerString
 FROM RMON-MIB
 entPhysicalIndex
 FROM ENTITY-MIB;

powerCharacteristicsMIB MODULE-IDENTITY

 LAST-UPDATED "201210220000Z" -- 22 October 2012

 ORGANIZATION "IETF EMAN Working Group"

 CONTACT-INFO

 "WG charter:

<http://datatracker.ietf.org/wg/eman/charter/>

 Mailing Lists:

 General Discussion: eman@ietf.org

 To Subscribe:

<https://www.ietf.org/mailman/listinfo/eman>

Internet-Draft <Power and Energy Monitoring MIB> October 2012
Archive:
<http://www.ietf.org/mail-archive/web/eman>

Editors:

Mouli Chandramouli
Cisco Systems, Inc.
Sarjapur Outer Ring Road
Bangalore 560103
IN
Phone: +91 80 4429 2409
Email: moulchan@cisco.com

Brad Schoening
44 Rivers Edge Drive
Little Silver, NJ 07739
US
Email: brad.schoening@verizon.net

Juergen Quittek
NEC Europe Ltd.
NEC Laboratories Europe
Network Research Division
Kurfuersten-Anlage 36
Heidelberg 69115
DE
Phone: +49 6221 4342-115
Email: quittek@neclab.eu

Thomas Dietz
NEC Europe Ltd.
NEC Laboratories Europe
Network Research Division
Kurfuersten-Anlage 36
69115 Heidelberg
DE
Phone: +49 6221 4342-128
Email: Thomas.Dietz@nw.neclab.eu

Benoit Claise
Cisco Systems, Inc.
De Kleetlaan 6a b1
Degem 1831
Belgium
Phone: +32 2 704 5622
Email: bclaise@cisco.com

DESCRIPTION

Internet-Draft <Power and Energy Monitoring MIB> October 2012
"This MIB is used to report AC power characteristics
in devices. The table is a sparse augmentation of
the eoPowerTable table from the energyObjectMib
module. Both three-phase and single-phase power
configurations are supported.

As a requirement for this MIB module,
[EMAN-AWARE-MIB] should be implemented.

Module Compliance of ENTITY-MIB v4
with respect to entity4CRCompliance should
be supported which requires implementation
of 3 MIB objects (entPhysicalIndex,
entPhysicalName and entPhysicalUUID)."

REVISION

"201210220000Z" -- 22 October 2012

DESCRIPTION

"Initial version, published as RFC YYY."

::= { mib-2 yyy }

powerCharacteristicsMIBConform OBJECT IDENTIFIER
::= { powerCharacteristicsMIB 0 }

powerCharacteristicsMIBObjects OBJECT IDENTIFIER
::= { powerCharacteristicsMIB 1 }

-- Objects

eoACPwrCharacteristicsTable OBJECT-TYPE

SYNTAX SEQUENCE OF EoACPwrCharacteristicsEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"This table defines power characteristics measurements
for supported entPhysicalIndex entities. It is a sparse
extension of the eoPowerTable."

::= { powerCharacteristicsMIBObjects 1 }

eoACPwrCharacteristicsEntry OBJECT-TYPE

SYNTAX EoACPwrCharacteristicsEntry

Internet-Draft <Power and Energy Monitoring MIB> October 2012

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"This is a sparse extension of the eoPowerTable with entries for power characteristics measurements or configuration. Each measured value corresponds to an attribute in IEC 61850-7-4 for non-phase measurements within the object MMUX."

INDEX {entPhysicalIndex }

 ::= { eoACPwrCharacteristicsTable 1 }

EoACPwrCharacteristicsEntry ::= SEQUENCE {

eoACPwrCharacteristicsConfiguration	INTEGER,
eoACPwrCharacteristicsAvgVoltage	Integer32,
eoACPwrCharacteristicsAvgCurrent	Integer32,
eoACPwrCharacteristicsFrequency	Integer32,
eoACPwrCharacteristicsPowerUnitMultiplier	UnitMultiplier,
eoACPwrCharacteristicsPowerAccuracy	Integer32,
eoACPwrCharacteristicsTotalActivePower	Integer32,
eoACPwrCharacteristicsTotalReactivePower	Integer32,
eoACPwrCharacteristicsTotalApparentPower	Integer32,
eoACPwrCharacteristicsTotalPowerFactor	Integer32,
eoACPwrCharacteristicsThdAmperes	Integer32,
eoACPwrCharacteristicsThdVoltage	Integer32

}

eoACPwrCharacteristicsConfiguration OBJECT-TYPE

SYNTAX INTEGER {

 sngl(1),

 del(2),

 wye(3)

}

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"Configuration describes the physical configurations of the power supply lines:

- * alternating current, single phase (SNGL)
- * alternating current, three phase delta (DEL)
- * alternating current, three phase Y (WYE)

Three-phase configurations can be either connected in a triangular delta (DEL) or star Y (WYE) system. WYE systems have a shared neutral voltage, while DEL systems do not. Each phase is offset 120 degrees to each other."

```
::= { eoACPwrCharacteristicsEntry 1 }

eoACPwrCharacteristicsAvgVoltage OBJECT-TYPE
    SYNTAX      Integer32
    UNITS       "0.1 Volt AC"
    MAX-ACCESS  read-only
    STATUS      current
    DESCRIPTION
        "A measured value for average of the voltage measured
        over an integral number of AC cycles. For a 3-phase
        system, this is the average voltage (V1+V2+V3)/3. IEC
        61850-7-4 measured value attribute 'Vol'"
    ::= { eoACPwrCharacteristicsEntry 2 }

eoACPwrCharacteristicsAvgCurrent OBJECT-TYPE
    SYNTAX      Integer32
    UNITS       "Amperes"
    MAX-ACCESS  read-only
    STATUS      current
    DESCRIPTION
        "A measured value of the current per phase. IEC 61850-
        7-4 attribute 'Amp'"
    ::= { eoACPwrCharacteristicsEntry 3 }

eoACPwrCharacteristicsFrequency OBJECT-TYPE
    SYNTAX      Integer32 (4500..6500) -- UNITS 0.01 Hertz
    UNITS       "hertz"
    MAX-ACCESS  read-only
    STATUS      current
    DESCRIPTION
        "A measured value for the basic frequency of the AC
        circuit. IEC 61850-7-4 attribute 'Hz'."
    ::= { eoACPwrCharacteristicsEntry 4 }

eoACPwrCharacteristicsPowerUnitMultiplier OBJECT-TYPE
    SYNTAX      UnitMultiplier
    MAX-ACCESS  read-only
    STATUS      current
    DESCRIPTION
        "The magnitude of watts for the usage value in
        eoACPwrCharacteristicsTotalActivePower,
        eoACPwrCharacteristicsTotalReactivePower
        and eoACPwrCharacteristicsTotalApparentPower
        measurements.
        For 3-phase power systems, this will also include
        eoACPwrCharacteristicsPhaseActivePower,
        eoACPwrCharacteristicsPhaseReactivePower and
        eoACPwrCharacteristicsPhaseApparentPower"
```


Internet-Draft <Power and Energy Monitoring MIB> October 2012
 ::= { eoACPwrCharacteristicsEntry 5 }

eoACPwrCharacteristicsPowerAccuracy OBJECT-TYPE

SYNTAX Integer32 (0..10000)
UNITS "hundredths of percent"
MAX-ACCESS read-only
STATUS current
DESCRIPTION

"This object indicates a percentage value, in 100ths of a percent, representing the presumed accuracy of active, reactive, and apparent power usage reporting. For example: 1010 means the reported usage is accurate to +/- 10.1 percent. This value is zero if the accuracy is unknown.

ANSI and IEC define the following accuracy classes for power measurement: IEC 62053-22 & 60044-1 class 0.1, 0.2, 0.5, 1 & 3.

ANSI C12.20 class 0.2 & 0.5"

::= { eoACPwrCharacteristicsEntry 6 }

eoACPwrCharacteristicsTotalActivePower OBJECT-TYPE

SYNTAX Integer32
UNITS " watts"
MAX-ACCESS read-only
STATUS current
DESCRIPTION

"A measured value of the actual power delivered to or consumed by the load. IEC 61850-7-4 attribute 'TotW'."

::= { eoACPwrCharacteristicsEntry 7 }

eoACPwrCharacteristicsTotalReactivePower OBJECT-TYPE

SYNTAX Integer32
UNITS "volt-amperes reactive"
MAX-ACCESS read-only
STATUS current
DESCRIPTION

"A measured value of the reactive portion of the apparent power. IEC 61850-7-4 attribute 'TotVAR'."

::= { eoACPwrCharacteristicsEntry 8 }

eoACPwrCharacteristicsTotalApparentPower OBJECT-TYPE

SYNTAX Integer32
UNITS "volt-amperes"
MAX-ACCESS read-only
STATUS current
DESCRIPTION

Internet-Draft <Power and Energy Monitoring MIB> October 2012

"A measured value of the voltage and current which determines the apparent power. The apparent power is the vector sum of real and reactive power.

Note: watts and volt-amperes are equivalent units and may be combined. IEC 61850-7-4 attribute 'TotVA'."

::= { eoACPwrCharacteristicsEntry 9 }

eoACPwrCharacteristicsTotalPowerFactor OBJECT-TYPE

SYNTAX Integer32 (-10000..10000)

UNITS "hundredths of percent"

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"A measured value ratio of the real power flowing to the load versus the apparent power. It is dimensionless and expressed here as a percentage value in 100ths of a percent. A power factor of 100% indicates there is no inductance load and thus no reactive power. Power Factor can be positive or negative, where the sign should be in lead/lag (IEEE) form. IEC 61850-7-4 attribute 'TotPF'."

::= { eoACPwrCharacteristicsEntry 10 }

eoACPwrCharacteristicsThdAmperes OBJECT-TYPE

SYNTAX Integer32 (0..10000)

UNITS "hundredths of percent"

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"A calculated value for the current total harmonic distortion (THD). Method of calculation is not specified. IEC 61850-7-4 attribute 'ThdAmp'."

::= { eoACPwrCharacteristicsEntry 11 }

eoACPwrCharacteristicsThdVoltage OBJECT-TYPE

SYNTAX Integer32 (0..10000)

UNITS "hundredths of percent"

MAX-ACCESS read-only

STATUS current

DESCRIPTION

"A calculated value for the voltage total harmonic distortion (THD). Method of calculation is not specified. IEC 61850-7-4 attribute 'ThdVol'."

::= { eoACPwrCharacteristicsEntry 12 }

eoACPwrCharacteristicsPhaseTable OBJECT-TYPE

SYNTAX SEQUENCE OF EoACPwrCharacteristicsPhaseEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"This table describes 3-phase power characteristics measurements. It is a sparse extension of the eoACPwrCharacteristicsTable."

::= { powerCharacteristicsMIBObjects 2 }

eoACPwrCharacteristicsPhaseEntry OBJECT-TYPE

SYNTAX EoACPwrCharacteristicsPhaseEntry

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

"An entry describes common 3-phase power characteristics measurements."

This optional table describes 3-phase power characteristics measurements, with three entries for each supported entPhysicalIndex entity. Entities having single phase power shall not have any entities.

This table describes attributes common to both WYE and DEL. Entities having single phase power shall not have any entries here. It is a sparse extension of the eoACPwrCharacteristicsTable.

These attributes correspond to IEC 61850-7.4 MMXU phase measurements."

INDEX { entPhysicalIndex, eoPhaseIndex }

::= { eoACPwrCharacteristicsPhaseTable 1 }

EoACPwrCharacteristicsPhaseEntry ::= SEQUENCE {

eoPhaseIndex Integer32,

eoACPwrCharacteristicsPhaseAvgCurrent Integer32,

eoACPwrCharacteristicsPhaseActivePower Integer32,

eoACPwrCharacteristicsPhaseReactivePower Integer32,

eoACPwrCharacteristicsPhaseApparentPower Integer32,

eoACPwrCharacteristicsPhasePowerFactor Integer32,

eoACPwrCharacteristicsPhaseImpedance Integer32

}

eoPhaseIndex OBJECT-TYPE

SYNTAX Integer32 (0..359)

MAX-ACCESS not-accessible

STATUS current

DESCRIPTION

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 "A phase angle typically corresponding to 0, 120, 240."
 ::= { eoACPwrCharacteristicsPhaseEntry 1 }

eoACPwrCharacteristicsPhaseAvgCurrent OBJECT-TYPE
 SYNTAX Integer32
 UNITS "Amperes"
 MAX-ACCESS read-only
 STATUS current
 DESCRIPTION
 "A measured value of the current per phase. IEC 61850-
 7-4 attribute 'A'"
 ::= { eoACPwrCharacteristicsPhaseEntry 2 }

eoACPwrCharacteristicsPhaseActivePower OBJECT-TYPE
 SYNTAX Integer32
 UNITS " watts"
 MAX-ACCESS read-only
 STATUS current
 DESCRIPTION
 "A measured value of the actual power delivered to or
 consumed by the load. IEC 61850-7-4 attribute 'W'"
 ::= { eoACPwrCharacteristicsPhaseEntry 3 }

eoACPwrCharacteristicsPhaseReactivePower OBJECT-TYPE
 SYNTAX Integer32
 UNITS "volt-amperes reactive"
 MAX-ACCESS read-only
 STATUS current
 DESCRIPTION
 "A measured value of the reactive portion of the
 apparent power. IEC 61850-7-4 attribute 'VAr'"
 ::= { eoACPwrCharacteristicsPhaseEntry 4 }

eoACPwrCharacteristicsPhaseApparentPower OBJECT-TYPE
 SYNTAX Integer32
 UNITS "volt-amperes"
 MAX-ACCESS read-only
 STATUS current
 DESCRIPTION
 "A measured value of the voltage and current determines
 the apparent power. Active plus reactive power equals
 the total apparent power.

 Note: Watts and volt-amperes are equivalent units and
 may be combined. IEC 61850-7-4 attribute 'VA'."
 ::= { eoACPwrCharacteristicsPhaseEntry 5 }

eoACPwrCharacteristicsPhasePowerFactor OBJECT-TYPE

```

Internet-Draft    <Power and Energy Monitoring MIB>   October 2012
SYNTAX            Integer32 (-10000..10000)
UNITS             "hundredths of percent"
MAX-ACCESS        read-only
STATUS            current
DESCRIPTION
    "A measured value ratio of the real power flowing to
    the load versus the apparent power for this phase.  IEC
    61850-7-4 attribute 'PF'. Power Factor can be positive
    or negative where the sign should be in lead/lag (IEEE)
    form."
    ::= { eoACPwrCharacteristicsPhaseEntry 6 }

eoACPwrCharacteristicsPhaseImpedance OBJECT-TYPE
    SYNTAX            Integer32
    UNITS             "volt-amperes"
    MAX-ACCESS        read-only
    STATUS            current
    DESCRIPTION
    "A measured value of the impedance.  IEC 61850-7-4 attribute
    'Z'."
    ::= { eoACPwrCharacteristicsPhaseEntry 7 }

eoACPwrCharacteristicsDelPhaseTable OBJECT-TYPE
    SYNTAX            SEQUENCE OF
EoACPwrCharacteristicsDelPhaseEntry
    MAX-ACCESS        not-accessible
    STATUS            current
    DESCRIPTION
    "This table describes DEL configuration phase-to-phase
    power characteristics measurements.  This is a sparse
    extension of the eoACPwrCharacteristicsPhaseTable."
    ::= { powerCharacteristicsMIBObjects 3 }

eoACPwrCharacteristicsDelPhaseEntry OBJECT-TYPE
    SYNTAX            EoACPwrCharacteristicsDelPhaseEntry
    MAX-ACCESS        not-accessible
    STATUS            current
    DESCRIPTION
    "An entry describes power characteristics attributes of
    a phase in a DEL 3-phase power system.  Voltage
    measurements are provided both relative to each other
    and zero.

    Measured values are from IEC 61850-7-2 MMUX and THD from
    MHAI objects.

```

Internet-Draft <Power and Energy Monitoring MIB> October 2012
 For phase-to-phase measurements, the eoPhaseIndex is
 compared against the following phase at +120 degrees.
 Thus, the possible values are:

eoPhaseIndex	Next Phase Angle
0	120
120	240
240	0

"

```
INDEX { entPhysicalIndex, eoPhaseIndex}
 ::= { eoACPwrCharacteristicsDelPhaseTable 1}
```

```
EoACPwrCharacteristicsDelPhaseEntry ::= SEQUENCE {
    eoACPwrCharacteristicsDelPhaseToNextPhaseVoltage
    Integer32,
    eoACPwrCharacteristicsDelThdPhaseToNextPhaseVoltage
    Integer32,
    eoACPwrCharacteristicsDelThdCurrent
    Integer32
}
```

```
eoACPwrCharacteristicsDelPhaseToNextPhaseVoltage OBJECT-TYPE
    SYNTAX      Integer32
    UNITS       "0.1 Volt AC"
    MAX-ACCESS  read-only
    STATUS      current
    DESCRIPTION
        "A measured value of phase to next phase voltages, where
         the next phase is IEC 61850-7-4 attribute 'PPV'."
    ::= { eoACPwrCharacteristicsDelPhaseEntry 2 }
```

```
eoACPwrCharacteristicsDelThdPhaseToNextPhaseVoltage OBJECT-TYPE
    SYNTAX      Integer32 (0..10000)
    UNITS       "hundredths of percent"
    MAX-ACCESS  read-only
    STATUS      current
    DESCRIPTION
        "A calculated value for the voltage total harmonic
         disortion for phase to next phase. Method of calculation
         is not specified. IEC 61850-7-4 attribute 'ThdPPV'."
    ::= { eoACPwrCharacteristicsDelPhaseEntry 3 }
```

```
eoACPwrCharacteristicsDelThdCurrent OBJECT-TYPE
    SYNTAX      Integer32 (0..10000)
    UNITS       "hundredths of percent"
    MAX-ACCESS  read-only
    STATUS      current
    DESCRIPTION
```

```

Internet-Draft    <Power and Energy Monitoring MIB>  October 2012
    "A calculated value for the voltage total harmonic
    distortion (THD) for phase to phase.  Method of
    calculation is not specified.
    IEC 61850-7-4 attribute 'ThdPPV'."
    ::= { eoACPwrCharacteristicsDelPhaseEntry 4 }

eoACPwrCharacteristicsWyePhaseTable OBJECT-TYPE
    SYNTAX          SEQUENCE OF
    EoACPwrCharacteristicsWyePhaseEntry
    MAX-ACCESS      not-accessible
    STATUS          current
    DESCRIPTION
        "This table describes WYE configuration phase-to-neutral
        power characteristics measurements.  This is a sparse
        extension of the eoACPwrCharacteristicsPhaseTable."
    ::= { powerCharacteristicsMIBObjects 4 }

eoACPwrCharacteristicsWyePhaseEntry OBJECT-TYPE
    SYNTAX          EoACPwrCharacteristicsWyePhaseEntry
    MAX-ACCESS      not-accessible
    STATUS          current
    DESCRIPTION
        "This table describes measurements of WYE configuration
        with phase to neutral power characteristics attributes.
        Three entries are required for each supported
        entPhysicalIndex entry.  Voltage measurements are
        relative to neutral.

        This is a sparse extension of the
        eoACPwrCharacteristicsPhaseTable.

        Each entry describes power characteristics attributes of
        one phase of a WYE 3-phase power system.

        Measured values are from IEC 61850-7-2 MMUX and THD from
        MHAI objects."
    INDEX { entPhysicalIndex, eoPhaseIndex }
    ::= { eoACPwrCharacteristicsWyePhaseTable 1}

EoACPwrCharacteristicsWyePhaseEntry ::= SEQUENCE {
    eoACPwrCharacteristicsWyePhaseToNeutralVoltage
    Integer32,
    eoACPwrCharacteristicsWyePhaseCurrent
    Integer32,
    eoACPwrCharacteristicsWyeThdPhaseToNeutralVoltage
    Integer32
}

```

```

Internet-Draft    <Power and Energy Monitoring MIB>   October 2012
eoACPwrCharacteristicsWyePhaseToNeutralVoltage OBJECT-TYPE
    SYNTAX          Integer32
    UNITS            "0.1 Volt AC"
    MAX-ACCESS      read-only
    STATUS           current
    DESCRIPTION
        "A measured value of phase to neutral voltage.  IEC
        61850-7-4 attribute 'PhV'."
    ::= { eoACPwrCharacteristicsWyePhaseEntry 1 }

eoACPwrCharacteristicsWyePhaseCurrent OBJECT-TYPE
    SYNTAX          Integer32
    UNITS            "0.1 ampheres AC"
    MAX-ACCESS      read-only
    STATUS           current
    DESCRIPTION
        "A measured value of phase currents.  IEC 61850-7-4
        attribute 'A'."
    ::= { eoACPwrCharacteristicsWyePhaseEntry 2 }

eoACPwrCharacteristicsWyeThdPhaseToNeutralVoltage OBJECT-TYPE
    SYNTAX          Integer32 (0..10000)
    UNITS            "hundredths of percent"
    MAX-ACCESS      read-only
    STATUS           current
    DESCRIPTION
        "A calculated value of the voltage total harmonic
        distortion (THD) for phase to neutral.  IEC 61850-7-4
        attribute 'ThdPhV'."
    ::= { eoACPwrCharacteristicsWyePhaseEntry 3 }

-- Conformance

powerCharacteristicsMIBCompliances OBJECT IDENTIFIER
    ::= { powerCharacteristicsMIB 2 }

powerCharacteristicsMIBGroups OBJECT IDENTIFIER
    ::= { powerCharacteristicsMIB 3 }

powerCharacteristicsMIBFullCompliance MODULE-COMPLIANCE
    STATUS           current
    DESCRIPTION
        "When this MIB is implemented with support for read-create,
        then such an implementation can claim full compliance.
        Such devices can then be both monitored and configured with
        this MIB."

```


Internet-Draft <Power and Energy Monitoring MIB> October 2012
Module Compliance of [EMAN-ENTITY] with respect to
entity4CRCompliance should be supported which requires
implementation of 3 MIB objects (entPhysicalIndex,
entPhysicalName and entPhysicalUUID)."

```
MODULE          -- this module
MANDATORY-GROUPS {
    powerACPwrCharacteristicsMIBTableGroup
}
```

```
GROUP          powerACPwrCharacteristicsOptionalMIBTableGroup
DESCRIPTION
    "A compliant implementation does not have
    to implement."
```

```
GROUP          powerACPwrCharacteristicsPhaseMIBTableGroup
DESCRIPTION
    "A compliant implementation does not have to
    implement."
```

```
GROUP          powerACPwrCharacteristicsDelPhaseMIBTableGroup
DESCRIPTION
    "A compliant implementation does not have to
    implement."
```

```
GROUP          powerACPwrCharacteristicsWyePhaseMIBTableGroup
DESCRIPTION
    "A compliant implementation does not have to
    implement."
```

```
::= { powerCharacteristicsMIBCompliances 1 }
```

-- Units of Conformance

```
powerACPwrCharacteristicsMIBTableGroup OBJECT-GROUP
    OBJECTS
        {
            -- Note that object entPhysicalIndex is NOT
            -- included since it is not-accessible

            eoACPwrCharacteristicsAvgVoltage,
            eoACPwrCharacteristicsAvgCurrent,
```

```

        eoACPwrCharacteristicsFrequency,

        eoACPwrCharacteristicsPowerUnitMultiplier,
        eoACPwrCharacteristicsPowerAccuracy,
        eoACPwrCharacteristicsTotalActivePower,

        eoACPwrCharacteristicsTotalReactivePower,

        eoACPwrCharacteristicsTotalApparentPower,
        eoACPwrCharacteristicsTotalPowerFactor
    }

    STATUS          current
    DESCRIPTION
        "This group contains the collection of all the power
        characteristics objects related to the Energy Object."
    ::= { powerCharacteristicsMIBGroups 1 }

powerACPwrCharacteristicsOptionalMIBTableGroup OBJECT-GROUP
    OBJECTS          {
        eoACPwrCharacteristicsConfiguration,
        eoACPwrCharacteristicsThdAmperes,
        eoACPwrCharacteristicsThdVoltage
    }
    STATUS          current
    DESCRIPTION
        "This group contains the collection of all the power
        characteristics objects related to the Energy Object."
    ::= { powerCharacteristicsMIBGroups 2 }

powerACPwrCharacteristicsPhaseMIBTableGroup OBJECT-GROUP
    OBJECTS          {
        -- Note that object entPhysicalIndex is
        -- NOT included since it is
        -- not-accessible
        eoACPwrCharacteristicsPhaseAvgCurrent,
        eoACPwrCharacteristicsPhaseActivePower,

        eoACPwrCharacteristicsPhaseReactivePower,

        eoACPwrCharacteristicsPhaseApparentPower,
        eoACPwrCharacteristicsPhasePowerFactor,

        eoACPwrCharacteristicsPhaseImpedance
    }
    STATUS          current
    DESCRIPTION

```

```

Internet-Draft    <Power and Energy Monitoring MIB>  October 2012
    "This group contains the collection of all 3-phase power
    characteristics objects related to the Power State."
    ::= { powerCharacteristicsMIBGroups 3 }

powerACPwrCharacteristicsDelPhaseMIBTableGroup OBJECT-GROUP
    OBJECTS
        {
            -- Note that object entPhysicalIndex and
            -- eoPhaseIndex are NOT included
            -- since they are not-accessible

eoACPwrCharacteristicsDelPhaseToNextPhaseVoltage ,

eoACPwrCharacteristicsDelThdPhaseToNextPhaseVoltage,
            eoACPwrCharacteristicsDelThdCurrent
        }
    STATUS          current
    DESCRIPTION
        "This group contains the collection of all power
        characteristic attributes of a phase in a DEL 3-phase
        power system."
    ::= { powerCharacteristicsMIBGroups 4 }

powerACPwrCharacteristicsWyePhaseMIBTableGroup OBJECT-GROUP
    OBJECTS
        {
            -- Note that object entPhysicalIndex and
            -- eoPhaseIndex are NOT included
            -- since they are not-accessible

eoACPwrCharacteristicsWyePhaseToNeutralVoltage,
            eoACPwrCharacteristicsWyePhaseCurrent,

eoACPwrCharacteristicsWyeThdPhaseToNeutralVoltage
        }
    STATUS          current
    DESCRIPTION
        "This group contains the collection of all WYE
        configuration phase-to-neutral power characteristics
        measurements."
    ::= { powerCharacteristicsMIBGroups 5 }

END

```

11. Security Considerations

Some of the readable objects in these MIB modules (i.e., objects with a MAX-ACCESS other than not-accessible) may be considered sensitive or vulnerable in some network environments. It is

Internet-Draft <Power and Energy Monitoring MIB> October 2012
thus important to control even GET and/or NOTIFY access to these
objects and possibly to even encrypt the values of these objects
when sending them over the network via SNMP.

There are a number of management objects defined in these MIB
modules with a MAX-ACCESS clause of read-write and/or read-
create. Such objects MAY be considered sensitive or vulnerable
in some network environments. The support for SET operations in
a non-secure environment without proper protection can have a
negative effect on network operations. The following are the
tables and objects and their sensitivity/vulnerability:

- Unauthorized changes to the eoPowerOperState (via
theeoPowerAdminState) MAY disrupt the power settings of the
differentEnergy Objects, and therefore the state of
functionality of the respective Energy Objects.
- Unauthorized changes to the eoEnergyParametersTable MAY
disrupt energy measurement in the eoEnergyTable table.

SNMP versions prior to SNMPv3 did not include adequate security.
Even if the network itself is secure (for example, by using
IPsec), there is still no secure control over who on the secure
network is allowed to access and GET/SET
(read/change/create/delete) the objects in these MIB modules.

It is RECOMMENDED that implementers consider the security
features as provided by the SNMPv3 framework (see [RFC3410],
section 8), including full support for the SNMPv3 cryptographic
mechanisms (for authentication and privacy).

Further, deployment of SNMP versions prior to SNMPv3 is NOT
RECOMMENDED. Instead, it is RECOMMENDED to deploy SNMPv3 and to
enable cryptographic security. It is then a customer/operator
responsibility to ensure that the SNMP entity giving access to
an instance of these MIB modules is properly configured to give
access to the objects only to those principals (users) that have
legitimate rights to GET or SET (change/create/delete) them.

12. IANA Considerations

12.1. IANA Considerations for the MIB Modules

The MIB modules in this document uses the following IANA-
assigned OBJECT IDENTIFIER values recorded in the SMI Numbers
registry:

Descriptor	OBJECT IDENTIFIER value
energyObjectMib	{ mib-2 xxx }
powerCharacteristicsMIB	{ mib-2 yyy }

Additions to the MIB modules are subject to Expert Review [RFC5226], i.e., review by one of a group of experts designated by an IETF Area Director. The group of experts MUST check the requested MIB objects for completeness and accuracy of the description. Requests for MIB objects that duplicate the functionality of existing objects SHOULD be declined. The smallest available OIDs SHOULD be assigned to the new MIB objects. The specification of new MIB objects SHOULD follow the structure specified in Section 10. and MUST be published using a well-established and persistent publication medium.

12.2. IANA Registration of new Power State Set

This document specifies an initial set of Power State Sets. The list of these Power State Sets with their numeric identifiers is given in Section 5.2.1. IANA maintains a Textual Convention IANAPowerStateSet with the initial set of Power State Sets and the Power States within those Power State Sets. The current version of Textual convention can be accessed <http://www.iana.org/assignments/IANAPowerStateSet>

New Assignments to Power State Sets shall be administered by IANA and the guidelines and procedures are listed in this Section.

New assignments for Power State Set will be administered by IANA through Expert Review [RFC5226], i.e., review by one of a group of experts designated by an IETF Area Director. The group of experts MUST check the requested state for completeness and accuracy of the description. A pure vendor specific implementation of Power State Set shall not be adopted; since it would lead to proliferation of Power State Sets.

12.2.1. IANA Registration of the IEEE1621 Power State Set

This document specifies a set of values for the IEEE1621 Power State Set [IEEE1621]. The list of these values with their identifiers is given in Section 5.2.1. The Internet Assigned Numbers Authority (IANA) created a new registry for IEEE1621

Internet-Draft <Power and Energy Monitoring MIB> October 2012
Power State Set identifiers and filled it with the initial
list in the Textual Convention IANA Power State Set..

New assignments (or potentially deprecation) for IEEE1621 Power State Set will be administered by IANA through Expert Review [RFC5226], i.e., review by one of a group of experts designated by an IETF Area Director. The group of experts MUST check the requested state for completeness and accuracy of the description.

12.2.2. IANA Registration of the DMTF Power State Set

This document specifies a set of values for the DMTF Power State Set. The list of these values with their identifiers is given in Section 5.2.1. The Internet Assigned Numbers Authority (IANA) has created a new registry for DMTF Power State Set identifiers and filled it with the initial list in the Textual Convention IANA Power State Set.

New assignments (or potentially deprecation) for DMTF Power State Set will be administered by IANA through Expert Review [RFC5226], i.e., review by one of a group of experts designated by an IETF Area Director. The group of experts MUST check the conformance with the DMTF standard [DMTF], on the top of checking for completeness and accuracy of the description.

12.2.3. IANA Registration of the EMAN Power State Set

This document specifies a set of values for the EMAN Power State Set. The list of these values with their identifiers is given in Section 5.2.1. The Internet Assigned Numbers Authority (IANA) has created a new registry for EMAN Power State Set identifiers and filled it with the initial list in the Textual Convention IANA Power State Set.

New assignments (or potentially deprecation) for EMAN Power State Set will be administered by IANA through Expert Review [RFC5226], i.e., review by one of a group of experts designated by an IETF Area Director. The group of experts MUST check the requested state for completeness and accuracy of the description.

12.3. Updating the Registration of Existing Power State Sets

IANA maintains a Textual Convention IANA Power State Set with the initial set of Power State Sets and the Power States within those Power State Sets. The current version of Textual convention can be accessed
<http://www.iana.org/assignments/IANA Power State Set>

Internet-Draft <Power and Energy Monitoring MIB> October 2012
With the evolution of standards, over time, it may be important to deprecate some of the existing Power State Sets or some of the states within a Power State Set.

The registrant shall publish an Internet-draft or an individual submission with the clear specification on deprecation of Power State Sets or Power States registered with IANA. The deprecation shall be administered by IANA through Expert Review [RFC5226], i.e., review by one of a group of experts designated by an IETF Area Director. The process should also allow for a mechanism for cases where others have significant objections to claims on deprecation of a registration. In cases, where the registrant cannot be reached, IESG can designate an Expert to modify the IANA registry for the deprecation.

12. Contributors

This document results from the merger of two initial proposals. The following persons made significant contributions either in one of the initial proposals or in this document.

John Parello

Rolf Winter

Dominique Dudkowski

13. Acknowledgment

The authors would like to thank Shamita Pisal for her prototype of this MIB module, and her valuable feedback. The authors would like to Michael Brown for improving the text dramatically.

We would like to thank Juergen Schoenwalder for proposing the design of the Textual Convention for IANAPowerStateSet and Ira McDonald for his feedback. Thanks for the many comments on the design of the EnergyTable from Minoru Teraoka and Hiroto Ogaki.

14. Open Issues

Internet-Draft <Power and Energy Monitoring MIB> October 2012
OPEN ISSUE 1 check if all the requirements from [EMAN-REQ] are covered.

OPEN ISSUE 2 IANA Registered Power State Sets deferred to [EMAN-FMWK]

15. References

15.2. Normative References

- [RFC2119] S. Bradner, Key words for use in RFCs to Indicate Requirement Levels, BCP 14, RFC 2119, March 1997.
- [RFC2578] McCloghrie, K., Ed., Perkins, D., Ed., and J. Schoenwaelder, Ed., "Structure of Management Information Version 2 (SMIv2)", STD 58, RFC 2578, April 1999.
- [RFC2579] McCloghrie, K., Ed., Perkins, D., Ed., and J. Schoenwaelder, Ed., "Textual Conventions for SMIv2", STD 58, RFC 2579, April 1999.
- [RFC2580] McCloghrie, K., Perkins, D., and J. Schoenwaelder, "Conformance Statements for SMIv2", STD 58, RFC 2580, April 1999.
- [RFC3621] Berger, A., and D. Romascanu, "Power Ethernet MIB", RFC3621, December 2003.
- [RFC4133] Bierman, A. and K. McCloghrie, "Entity MIB (Version 3)", RFC 4133, August 2005.
- [LLDP-MED-MIB] ANSI/TIA-1057, "The LLDP Management Information Base extension module for TIA-TR41.4 media endpoint discovery information", July 2005.
- [EMAN-AWARE-MIB] J. Parello, and B. Claise, "draft-ietf-eman-energy-aware-mib-05 ", work in progress, March 2012.

15.3. Informative References

- Internet-Draft <Power and Energy Monitoring MIB> October 2012
[RFC1628] S. Bradner, "UPS Management Information Base", RFC 1628, May 1994
- [RFC3410] Case, J., Mundy, R., Partain, D., and B. Stewart, "Introduction and Applicability Statements for Internet Standard Management Framework ", RFC 3410, December 2002.
- [RFC3418] Presun, R., Case, J., McCloghrie, K., Rose, M, and S. Waldbusser, "Management Information Base (MIB) for the Simple Network Management Protocol (SNMP)", RFC3418, December 2002.
- [RFC3433] Bierman, A., Romascanu, D., and K. Norseth, "Entity Sensor Management Information Base", RFC 3433, December 2002.
- [RFC4268] Chisholm, S. and D. Perkins, "Entity State MIB", RFC 4268, November 2005.
- [RFC5226] Narten, T. Alverstrand, H., A. and K. McCloghrie, "Guidelines for Writing an IANA Considerations Section in RFCs ", BCP 26, RFC 5226, May 2008.
- [EMAN-REQ] Quittek, J., Winter, R., Dietz, T., Claise, B., and M. Chandramouli, " Requirements for Energy Management", draft-ietf-eman-requirements-09, October 2012.
- [EMAN-FMWK] Claise, B., Parello, J., Schoening, B., Quittek, J. and Nordman, B, "Energy Management Framework", draft-ietf-eman-framework-05, July 2012.
- [EMAN-MONITORING-MIB] M. Chandramouli, Schoening, B., Dietz, T., Quittek, J. and B. Claise "Energy and Power Monitoring MIB ", draft-ietf-eman-energy-monitoring-mib-03, July 2012.
- [EMAN-AS] Schoening, B., Chandramouli, M. and Nordman, B. "Energy Management (EMAN) Applicability Statement", draft-ietf-eman-applicability-statement-02, October 2012.
- [EMAN-ENTITY] A. Bierman, D. Romascanu, J. Quittek and M. Chandramouli " Entity MIB (Version 4)", draft-ietf-eman-rfc4133bis-03, October 2012.
- [EMAN-TERMINOLOGY] J. Parello, "Energy Management Terminology", draft-parello-eman-definitions-07, work in progress, October 2012.

- Internet-Draft <Power and Energy Monitoring MIB> October 2012
- [ACPI] "Advanced Configuration and Power Interface Specification", <http://www.acpi.info/DOWNLOADS/ACPIspec30b.pdf>
- [DMTF] "Power State Management Profile DMTF DSP1027 Version 2.0" December 2009
http://www.dmtf.org/sites/default/files/standards/documents/DSP1027_2.0.0.pdf
- [IEEE1621] "Standard for User Interface Elements in Power Control of Electronic Devices Employed in Office/Consumer Environments", IEEE 1621, December 2004.
- [IEC.61850-7-4] International Electrotechnical Commission, "Communication networks and systems for power utility automation Part 7-4: Basic communication structure Compatible logical node classes and data object classes", 2010.
- [IEC.62053-21] International Electrotechnical Commission, "Electricity metering equipment (a.c.) Particular requirements Part 22: Static meters for active energy (classes 1 and 2)", 2003.
- [IEC.62053-22] International Electrotechnical Commission, "Electricity metering equipment (a.c.) Particular requirements Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)", 2003.

Authors' Addresses

Mouli Chandramouli
Cisco Systems, Inc.
Sarjapur Outer Ring Road
Bangalore 560103
IN

Phone: +91 80 4429 2409
Email: moulchan@cisco.com

Brad Schoening
44 Rivers Edge Drive
Little Silver, NJ 07739

Internet-Draft <Power and Energy Monitoring MIB> October 2012
US
Email: brad.schoening@verizon.net

Juergen Quittek
NEC Europe Ltd.
NEC Laboratories Europe
Network Research Division
Kurfuersten-Anlage 36
Heidelberg 69115
DE

Phone: +49 6221 4342-115
Email: quittek@neclab.eu

Thomas Dietz
NEC Europe Ltd.
NEC Laboratories Europe
Network Research Division
Kurfuersten-Anlage 36
Heidelberg 69115
DE

Phone: +49 6221 4342-128
Email: Thomas.Dietz@neclab.eu

Benoit Claise
Cisco Systems, Inc.
De Kleetlaan 6a b1
Diegem 1813
BE

Phone: +32 2 704 5622
Email: bclaise@cisco.com